

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for February 2022

Issue Date: 30/01/2022

Issue Time: 1000 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2022 to 28th February 2022	00 - 24	8200	450	7750	3615	4135		
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT ii. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli stage2 iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

Natioanl Load Despatch Centre, New Delhi
Import Capability of S3 for February 2022

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2022 to 5th February 2022	00-24	3150	90	3060	2800	260	-150	Revision - 02 : Due to extension of 400kV Tirunelveli-Cochin-D/C shutdown
6th February 2022 to 28th February 2022	00-24	3300	90	3210	2800	410		
	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
Limiting Constraint (any one or	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for February 2022
Import Capability of S3 for February 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	26-10-2021	01-02-2022 to 28-02-2022	Revision-0
1	29-01-2022	01-02-2022 to 28-02-2022	1. Pole-4 of Raigarh-Pugalur commissioning 2.ISGS Outages approved in 186th OCC meeting
2	30-01-2022	01-02-2022 to 05-02-2022	Revision - 02 : Due to extension of 400kV Tirunelveli-Cochin-D/C shutdown

Change in quantumm w.r.t last revision (MW)	Corridor
	-
400	S1-(S2&S3)
-150	Import of S3