

National Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for July 2018

Issue Date: 04th July 2018

Issue Time: 1700 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2018 to 4th July 2018	00 - 24	8200	475	7725	4530	3195		
5th July 2018 to 6th July 2018	00 - 24	6015	431	5584	4199	1385	-2185	Due to outage of 400kV Somanahalli - Hosur D/C, and revised LGBR with outage of following units: KKNPP U 2, MAPS U 2, Talcher U 5, Ramagundam U-6, NTECL Vallur U-2, NLC TS2 Exp U-1, NLC TS2 U-2, Kaiga U-1, NTPL U-2, NLC TS2 U-5, NTPL U-2
7th July 2018 to 15th July 2018	00 - 24	6015	431	5584	4276	1308	-2185	
16th July 2018 to 28th July 2018	00 - 24	6015	431	5584	4499	1085	-2185	
29th July 2018 to 31st July 2018	00 - 24	6015	431	5584	4588	996	-2185	
Limiting Constraints (any one or combination thereof)	i. (n-1) of 765/400kV ICT at Tiruvalum.							
	ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iii. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	iv. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Scheme (SPS)							

National Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for July 2018

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2018 to 4th July 2018	00-24	2975	85	2890	2742	148		
5th July 2018 to 6th July 2018	00-24	2957	71	2886	2302	584		
7th July 2018 to 15th July 2018	00 - 24	2957	71	2886	2289	597		
16th July 2018 to 28th July 2018	00 - 24	2957	71	2886	2256	630		
29th July 2018 to 31st July 2018	00 - 24	2957	71	2886	2235	651		
Limiting Constraint (any one or combination)	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit *							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for July 2018
Transfer Capability for Import of S3 for July 2018

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
1	04th July 2018	05th to 31st July 2018	Due to outage of 400kV Somanahalli - Hosur D/C, and revised LGBR with outage of following units: KKNPP U 2, MAPS U 2, Talcher U 5, Ramagundam U-6, NTECL Vallur U-2, NLC TS2 Exp U-1, NLC TS2 U-2, Kaiga U-1, NTPL U-2, NLC TS2 U-5, NTPL U-2	S1-S2

