

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for June 2018

Issue Date: 31/05/2018

Issue Time: 2200 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2018 to 9th June 2018	00 - 24	7100	460	6640	4681	1959	-700	Revised due to change in LGBR, outage of 400kV Somanahalli - Hosur S/C and outage of following units: 1. KKNPP U 2 2. MAPS U 2 3. Talcher U 5 4. Ramagundam U-6 5. NTECL Vallur U-2 6. NLC TS1 Exp U-1 7. NLC TS2 U-6
10th June 2018 to 14th June 2018					4631	2009		
15th June 2018 to 18th June 2018					4453	2187		
19th June 2018 to 28th June 2018					4343	2297		
29th June 2018 to 30th June 2018					4420	2220		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit* iii. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit iv. (n-1) of 765/400kV ICT at Tiruvalum. v. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit vi. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

Natioanal Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for June 2018

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2018 to 9th June 2018	00-24	2910	90	2820	2404	416	-10	Revised due to change in LGBR, outage of 400kV Somanahalli - Hosur S/C and outage of following units: 1. KKNPP U 2 2. MAPS U 2 3. Talcher U 5 4. Ramagundam U-6 5. NTECL Vallur U-2 6. NLC TS1 Exp U-1 7. NLC TS2 U-6
10th June 2018 to 14th June 2018					2435	385		
15th June 2018 to 18th June 2018					2382	438		
19th June 2018 to 28th June 2018					2397	423		
29th June 2018 to 30th June 2018					2378	442		
Limiting Constraint (any)	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit * ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for June 2018
Transfer Capability for Import of S3 for June 2018

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
1	31/5/2018	01-06-2018 to 30-06-2018	Revised due to change in LGBR, outage of 400kV Somanahalli - Hosur S/C and outage of following units: 1. KKNPP U 2 2. MAPS U 2 3. Talcher U 5 4. Ramagundam U-6 5. NTECL Vallur U-2 6. NLC TS1 Exp U-1 7. NLC TS2 U-6	S1- (S2&S3)/Import of S3