

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for June 2021**

Issue Date: 22/06/2021

Issue Time: 1600 Hrs

Revision No. 16

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2021 to 4th June 2021	00 - 24	7200	450	6750	3585	3165		
5th June 2021	00 - 24	7500	450	7050	3585	3465		
6th June 2021	00 - 24	7500	450	7050	3585	3465		
7th June 2021 to 14th June 2021	00 - 24	7500	450	7050	3585	3465		
15th June 2021	00 - 24	7500	450	7050	3680	3370		
16th June 2021	00 - 24	7500	450	7050	3680	3370		
17-18 th June 2021	00 - 24	7500	450	7050	3680	3370		
19th June 2021	00 - 08	7500	450	7050	3680	3370		
	08 - 24	7100	450	6650	3680	2970		
20th June 2021	00 - 08	7500	450	7050	3680	3370		
	08 - 24	7100	450	6650	3680	2970		
21st June 2021	00 - 24	7500	450	7050	3680	3370		
22nd June 2021	00 - 08	7500	450	7050	3895	3155		
	08 - 24	7100	450	6650	3895	2755		
23rd June 2021	00 - 08	7500	450	7050	3895	3155		
	08 - 24	7100	450	6650	3895	2755		
24th June 2021	00 - 24	7100	450	6650	3895	2755	-400	Revision-16 : Due to shutdown of 800kV Raigarh-Pugulur Pole-1&2 for Bipole-2 testing
25th June 2021 to 30th June 2021	00 - 24	7500	450	7050	3895	3155		
Limiting Constraints (any one or combination thereof)	i. <b>From 1st June to 4th June:</b> N-1 violation of N-1 violation 2x315 MVA ICT at 400/230kV Salem ICT*.							
	ii. <b>From 5th June to 30th June:</b> N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability for Import of S3 for June 2021**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2021 to 2nd June 2021	00-24	3350	90	3260	2736	524		
3rd June 2021	00-08	3350	90	3260	2736	524		
	08 - 24	3200	90	3110	2736	374		
4th June 2021	00-08	3350	90	3260	2736	524		
	08-24	3120	90	3030	2736	294		
5th June 2021	00-24	3050	90	2960	2736	224		
6th June 2021	00-24	3350	90	3260	2736	524		
7th June 2021	00-08	3350	90	3260	2736	524		
	08-24	3120	90	3030	2736	294		
8th June 2021	00 -24	3120	90	3030	2736	294		
9th June 2021 to 14th June 2021	00-24	3350	90	3260	2736	524		
15th June 2021 to 21st June 2021	00-24	3350	90	3260	2714	546		
22nd June 2021 to 30th June 2021	00-24	3350	90	3260	2587	673		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	iii. (n-1) contingency of one circuit of 400 kV Tirunelveli - Trivandrum will lead to Low Voltage at Trivandrum							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for June 2021**  
**Transfer Capability for Import of S3 for June 2021**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-02-2021	01-06-2021 to 30-06-2021	Revision-0	-
1	30-05-2021	01-06-2021 to 30-06-2021	1.Commissioning of Raigarh-Pugalur HVDC Pole2 2.Commissioning of Pugalur-Trichur HVDC VSC Pole2 3.Considering generator outages approved in 178th OCC meeting of SR 4.Shut down of Raigarh-Pugalur Pole1&2 till 4th June	S1-->(S2nS3) and S3
2	02-06-2021	03-06-2021	Revision-2 : Shutdown of 400kV/220kV Cochin ICT-1	S3
3	03-06-2021	04-06-2021	Revision-3: Shutdown of 400kV/220kV Madakkathara ICT-2	S3
4	03-06-2021	05-06-2021	Revision-4 : Due to shutdown of 800kV Raigarh Pugulur -1 &2, 400kV/220kV Madakkathara ICT-2, 400kV Palakkad-Trichur-1	S1-(S2&S3) and S3
5	04-06-2021	06-06-2021	Revision 5 : Due to Shutdown of 800kV Raigarh-Pugulur-1&2	S1-(S2&S3)
6	04-06-2021	05-06-21 to 06-06-21	Revision 6 : TTC/ATC restored back due to revival of 800kV Raigarh-Pugulur-1&2	S1-(S2&S3)
7	05-06-2021	07-06-2021 to 08-06-2021	Revision - 7 : Due to shutdown of 400kV/220kV Madakkathara ICT-3 shutdown	S3
8	14-06-2021	16-06-2021	Revision - 8 : Due to shutdown of 800kV Raigarh-Pugulur Pole-1 & 2 for the testing of Pole-4	S1-(S2&S3)
9	15-06-2021	16-06-2021	Revision - 9 : TTC revised due to deferment of Raigarh-Pugulur Pole-4 testing	S1-(S2&S3)
10	15-06-2021	17-06-2021	Revision - 10 : Due to shutdown of 800kV Raigarh-Pugulur Pole-1 & 2 for the testing of Pole-4	S1-(S2&S3)
11	16-06-2021	17-06-2021	Revision - 11 : TTC revised due to deferment of Raigarh-Pugulur Pole-4 testing	S1-(S2&S3)
12	17-06-2021	19-06-2021	Revision - 12 : Due to shutdown of 800kV Raigarh-Pugulur Pole-1 & 2 for the testing of Pole-4	S1-(S2&S3)
13	18-06-2021	20-06-2021	Revision - 13 : Due to shutdown of 800kV Raigarh-Pugulur Pole-1 & 2 for the testing of Pole-4	S1-(S2&S3)
14	20-06-2021	22-06-2021	Revision-14 : Due to shutdown of 800kV Raigarh-Pugulur Pole-1&2 for Bipole-2 testing	S1-(S2&S3)
15	21-06-2021	23-06-2021	Revision-15 : Due to shutdown of 800kV Raigarh-Pugulur Pole-1&2 for Bipole-2 testing	S1-(S2&S3)
16	22-06-2021	24-06-2021	Revision-16 : Due to shutdown of 800kV Raigarh-Pugulur Pole-1&2 for Bipole-2 testing	S1-(S2&S3)