

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for June 2017

Issue Date: 29/05/2017

Issue Time: 1900 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2017 to 11th June 2017	00-24	6775	400	6375	4218	2157	-625	Revised considering LGBR submitted by constituents in the 131st OCCM and generator outages approved in OCCM.
11th June 2017 to 22nd June 2017					3883	2492		
23rd June 2017 to 24th June 2017					3663	2712		
25th June 2017 to 27th June 2017					3724	2651		
28th June 2017 to 30th June 2017					3633	2742		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit							
	ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iii. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit							
	iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	v. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for June 2017

Issue Date: 29/05/2017

Issue Time: 1900 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2017 to 11th June 2017	00-24	2970	80	2890	2138	752		Revised considering LGBR submitted by constituents in the 131st OCCM and generator outages approved in OCCM.
11th June 2017 to 22nd June 2017					2172	718		
23rd June 2017 to 24th June 2017					2303	587		
25th June 2017 to 27th June 2017					2265	625		
28th June 2017 to 30th June 2017					2287	603		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

**National Load Despatch Centre
 Transfer Capability between S1- (S2&S3) for June 2017
 Transfer Capability for Import of S3 for June 2017**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	23-Feb-17	01-06-2017 to 30-06-2017	-	-
1	29-May-17	01-06-2017 to 30-06-2018	Revised considering LGBR submitted by constituents in the 131st OCCM and generator outages approved in OCCM.	S1-(S2&S3) and Import of S3