

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for June 2017

Issue Date: 07/06/2017

Issue Time: 1400 hrs

Revision No. 5

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2017 to 7th June 2017	00-24	6775	400	6375	4218	2157		
8th June 2017	00-09	6775	400	6375	4218	2157		
	09-18	6620	400	6220	4218	2002	-155	Due to shutdown of 400kV MTPSII-Karamadai-I line
	18-24	6775	400	6375	4218	2157		
9th June 2017 to 11th June 2017	00-24	6775	400	6375	4218	2157		
11th June 2017 to 22nd June 2017	00-24	6775	400	6375	3883	2492		
23rd June 2017 to 24th June 2017	00-24	6775	400	6375	3663	2712		
25th June 2017 to 27th June 2017	00-24	6775	400	6375	3724	2651		
28th June 2017 to 30th June 2017	00-24	6775	400	6375	3633	2742		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit							
	ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iii. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit							
	iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	v. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for June 2017

Issue Date: 07/06/2017

Issue Time: 1400 hrs

Revision No. 5

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st June 2017 to 2nd June 2017	00-24	2970	80	2890	2138	752			
3rd June 2017 to 4th June 2017	00 -09 & 19 - 24	2970		2890		752			
	09 - 19	2670		2590		452			
5th June 2017 to 7th June 2017	00 -08 & 18 - 24	2970		2890		752			
	08 - 18	2670		2590		452			
8th June 2017 to 9th June 2017	00 -08 & 18 - 24	2970		2890		752			
	08 - 18	2670		2590		452	-300	Due to extension of shutdown of Edamon - Thirunelveli D/C	
10th June 2017 to 11th June 2017	00-24	2970		2890		2138	752		
11th June 2017 to 22nd June 2017	00-24	2970		2890	2172	718			
23rd June 2017 to 24th June 2017					2303	587			
25th June 2017 to 27th June 2017					2265	625			
28th June 2017 to 30th June 2017					2287	603			
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit ii. Low Voltage in Kerala (S3)								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and								

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for June 2017
Transfer Capability for Import of S3 for June 2017

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	23-Feb-17	01-06-2017 to 30-06-2017	Revision-0	-
1	29-May-17	01-06-2017 to 30-06-2017	Revised considering LGBR submitted by constituents in the 131st OCCM and generator outages approved in OCCM.	S1-(S2&S3) and Import of S3
2	6/1/2017	03-06-2017 to 07-06-2017	Due to 220kV Tirunelveli - Edamon D/C outage	Import of S3
3	6/4/2017	05-06-2017 to 07-06-2017	Due to 220kV Tirunelveli - Edamon D/C outage timings change	Import of S3
4	6/6/2017	6/8/2017	Due to shutdown of 400kV MTPSII-Karamadai-I line	S1-S2nS3
5	6/7/2017	08-06-2017 to 09-06-2017	Due to 220kV Tirunelveli - Edamon D/C outage	Import of S3