

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for March 2020

Issue Date: 02/03/2020

Issue Time: 1300 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2020 to 2nd March 2020	00 - 24	7300	490	6810	3609	3201		
3rd March 2020 to 18th March 2020	00 - 24	6950	490	6460	3794	2666	-350	Revised due to commissioning of 400kV Tirunelveli - Cochin -2 and CGS unit outages as decided in 164 OCCM.
19th March 2020 to 31st March 2020	00 - 24	6950	490	6460	3544	2916		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to Low Voltage at Palakkad/Trichur & (n-1) contingency of one circuit of 400 kV Tirunelveli-Cochin will lead to Low Voltage at Cochin/Trichur.							
	ii. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS							
	iii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for March 2020

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2020 to 2nd March 2020	00-24	3150	90	3060	2742	318		
3rd March 2020 to 18th March 2020	00-24	3300	90	3210	2624	586	150	Revised due to commissioning of 400kV Tirunelveli - Cochin -2 and CGS unit outages as decided in 164 OCCM.
19th March 2020 to 31st March 2020	00-24	3300	90	3210	2747	463		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to Low Voltage at Palakkad/Trichur							
	ii. (n-1) contingency of one circuit of 400 kV Tirunelveli-Cochin will lead to Low Voltage at Cochin/Trichur.							
	iii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for March 2020
Transfer Capability for Import of S3 for March 2020

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
1	3/2/2020	03-03-2020 to 31-03-2020	Revision-1. Revised due to commissioning of 400kV Tirunelveli - Cochin -2 and CGS unit outages as decided in 164 OCCM.	S1-(S2&S3) and Import of S3