

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for March 2022

Issue Date: 27/02/2022

Issue Time: 1000 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2022 to 23rd March 2022	00 - 24	8400	450	7950	3715	4235		
24th March 2022 to 31st March 2022	00 - 24	8400	450	7950	3965	3985		
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	ii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP							
	iii. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli stage2							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

Natioanl Load Despatch Centre, New Delhi
Import Capability of S3 for March 2022

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2022 to 3rd March 2022	00-24	3300	90	3210	2800	410		
4th March 2022 to 23rd March 2022	00-24	3300	90	3210	2658	552		
24th March 2022 to 31st March 2022	00-24	3300	90	3210	2537	673		
Limiting Constraint (any one or	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for March 2022
Import Capability of S3 for March 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-11-2021	01-03-2022 to 31-03-2022	Revision-0	-
1	27-02-2022	01-03-2022 to 31-03-2022	1.Updated network 2.ISGS Outages approved in 187th OCC Meeting of SRPC	1.S1- (S2&S3) 2.S3 Import
2	03-03-2022	04-03-2022 to 31-03-2022	Planned outage of Maithon power unit, the corresponding LTA quantum(142 MW) is released for STOA in S3 corridor	S3 Import