

Transfer Capability between S1- (S2&S3) for March 2026

Revision No. 0

[illegible]

Revision No. 0

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	Approved GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st to 31st Mar 2026	00-24	1-96	4575	120	4455	2679	1776	0	0
Limiting Constraint (any one or combination thereof)	i.	(n-1) contingency of one ICT of (2x315 MVA +1x500 MVA) 400/220kV ICT at Kozhikode SS will lead to over-loading of the Other ICT							
	ii.	(n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for March 2026
Import Capability of S3 for March 2026

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-03-2025	01-03-2026 to 31-03-2026	Revision-0	-