

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for May 2018

Issue Date: 30/04/2018

Issue Time: 1300 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2018 to 31st May 2018	00 - 24	6700	450	6250	4837	1413	-295	Revised due to change in Network Toplogy and Outage of 400kV Hosur-Somanahalli s/c & 400kV Mettur-Palavadi ckt-1
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400kV Kolar-Hosur leads to overloading of the other circuit.							
	ii. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad would lead to overloading of the other circuit							
	iii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for May 2018

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2018 to 31st May 2018	00-24	2900	80	2820	2568	252	-75	Revised due to change in Network Toplogy and Outage of 400kV Hosur-Somanahalli s/c & 400kV Mettur-Palavadi ckt-1
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for May 2018
Transfer Capability for Import of S3 for May 2018

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
1	30th Apr 2018	Whole Month	Revised due to change in Network Toplogy and Outage of 400kV Hosur-Somanahalli s/c & 400kV Mettur-Palavadi ckt-1	S1-(S2&S3), S3