

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for May 2021

Issue Date: 29/04/2021

Issue Time: 1700 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2021 to 8th May 2021	00 - 24	7650	450	7200	3452	3748		
9th May 2021 to 15th May 2021	00 - 24	7650	450	7200	3409	3791		
16th May 2021 to 16th May 2021	00 - 24	7650	450	7200	3486	3714		
17th May 2021 to 21st May 2021	00 - 24	7650	450	7200	3638	3562		
22nd May 2021 to 31st May 2021	00 - 24	7650	450	7200	3602	3598		
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	ii. N-1 violation of 400/230kV Thiruvallam 2x315 MVA ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

Natioanal Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for May 2021

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2021 to 8th May 2021	00-24	3300	90	3210	2716	494		
9th May 2021 to 15th May 2021	00-24	3300	90	3210	2723	487		
16th May 2021 to 16th May 2021	00-24	3300	90	3210	2745	465		
17th May 2021 to 21st May 2021	00-24	3300	90	3210	2786	424		
22nd May 2021 to 31st May 2021	00-24	3300	90	3210	2797	413		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for May 2021
Transfer Capability for Import of S3 for May 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-01-2021	01-05-2021 to 31-05-2021	Revision-0	-
1	29-04-21	01-05-2021 to 31-05-2021	1.Commissioning of HVDC Raigarh -Pugalur pole1&2 2.Commissioning of VSC Pugalur-Trissur Pole-2 3.Commissioning of 400kV Trissur-Kozikode D/C 4.Outages approved in 177th SRPC OCC considered	S1-(S2nS3) &S3