

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for May 2021

Issue Date: 06/05/2021

Issue Time: 1300 Hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2021 to 6th May 2021	00 - 24	7650	450	7200	3452	3748		
7th May 2021	00 - 08	7650	450	7200	3409	3791		
7th May 2021	08 - 24	6850	450	6400	3409	2991	-800	Revision-2 : Due to Bipole-1 outage of 800kV Raigarh-Pugulur HVDC for testing of Bipole-2
7th May 2021	00 - 08	7650	450	7200	3409	3791		
7th May 2021	08 - 24	7650	450	7200	3409	3791	800	Revision-3 : TTC/ATC restored back due to deferment of 800kV Raigarh Pugulur Bipole-2 testing
8th May 2021 to 31st May 2021	00 - 24	7650	450	7200	3638	3562		
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	ii. N-1 violation of 400/230kV Thiruvallam 2x315 MVA ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							