

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for May 2021**

Issue Date: 23/05/2021

Issue Time: 1000 Hrs

Revision No. 6

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2021 to 8th May 2021	00 - 24	7650	450	7200	3452	3748		
9th May 2021 to 15th May 2021	00 - 24	7650	450	7200	3409	3791		
16th May 2021 to 16th May 2021	00 - 24	7650	450	7200	3486	3714		
17th May 2021 to 21st May 2021	00 - 24	7650	450	7200	3638	3562		
22nd May 2021 to 23rd May 2021	00 - 24	7650	450	7200	3602	3598		
24th May 2021 to 31st May 2021	00 - 24	7650	450	7200	3602	3598	800	Revision-6 : Restored back TTC/ATC due to postpone of 800kV Raigarh-Pugulur -1 &2 shutdown in view of cyclone alerts to SR states
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT ii. N-1 violation of 400/230kV Thiruvallam 2x315 MVA ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability for Import of S3 for May 2021**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA)</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May 2021 to 8th May 2021	00-24	3300	90	3210	2716	494		
9th May 2021 to 15th May 2021	00-24	3300	90	3210	2723	487		
16th May 2021 to 16th May 2021	00-24	3300	90	3210	2745	465		
17th May 2021 to 21st May 2021	00-24	3300	90	3210	2786	424		
22nd May 2021 to 31st May 2021	00-24	3300	90	3210	2797	413		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for May 2021**  
**Transfer Capability for Import of S3 for May 2021**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor</b>
0	26-01-2021	01-05-2021 to 31-05-2021	Revision-0	-
1	29-04-2021	01-05-2021 to 31-05-2021	1.Commissioning of HVDC Raigarh -Pugalur pole1&2 2.Commissioning of VSC Pugalur-Trissur Pole-2 3.Commissioning of 400kV Trissur-Kozikode D/C 4.Outages approved in 177th SRPC OCC considered	S1-(S2nS3) &S3
2	06-05-2021	07-05-2021	Revision-2 : Due to Bipole-1 outage of 800kV Raigarh-Pugulur HVDC for testing of Bipole-2	S1-(S2nS3)
3	06-05-2021	07-05-2021	Revision-3 : TTC/ATC restored back due to deferment of 800kV Raigarh Pugulur Bipole-2 testing	S1-(S2nS3)
4	07-05-2021	08-05-2021 to 31-05-2021	1.Commissioning of HVDC Raigarh -Pugalur pole1&2 2.Commissioning of VSC Pugalur-Trissur Pole-2 3.Commissioning of 400kV Trissur-Kozikode D/C 4.Outages approved in 177th SRPC OCC considered	S1-(S2nS3) &S3
5	22-05-2021	24-05-2021 to 31-05-2021	Due to 800kV Raigarh-Pugulur 1 & 2 shutdown	S1-(S2nS3) &S3
6	23-05-2021	24-05-2021 to 31-05-2021	Revision-6 : Restored back TTC/ATC due to postpone of 800kV Raigarh-Pugulur -1 &2 shutdown in view of cyclone alerts to SR states	S1-(S2nS3) &S3