Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for May 2022

Issue Date: 26/01/2022 Issue Time: 1800 Hrs Revision No. 0

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st May 2022 to 30th May 2022	00 - 24	8200	450	7750	3756	3994			
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT								
	ii. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2								
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

Natioanl Load Despatch Centre, New Delhi Import Capability of S3 for May2022

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 30th May 2022	00-24	3300	90	3210	2832	378		
Limiting Constraint (any one or	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre Transfer Capability between S1- (S2&S3) for May 2022 Import Capability of S3 for May2022

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-01-2022	01-05-2022 to 31-05-2022	Revision-0	-