

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for May 2022

Issue Date: 11/05/2022

Issue Time: 1500 Hrs

Revision No. 4

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 9th May 2022	00 - 24	8750	450	8300	4349	3951		
10th May 2022 to 19th May 2022	00 - 24	8750	450	8300	4427	3873		
20th May 2022 to 28th May 2022	00 - 24	8750	450	8300	4191	4109		
29th May 2022 to 31st May 2022	00 - 24	8750	450	8300	4395	3905		
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	ii. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2							
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

Natioanl Load Despatch Centre, New Delhi
Import Capability of S3 for May2022

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 02nd May 2022	00-24	3300	90	3210	2626	584		
03rd May 2022	00-08	3300	90	3210	2626	584		
	08-24	2950	90	2860	2626	234		
4th May 2022 to 9th May 2022	00-24	3300	90	3210	2626	584		
10th May 2022 to 12th May 2022	00-24	3300	90	3210	2647	563		
13th May 2022	00-08	3300	90	3210	2647	563		
	09-24	2950	90	2860	2647	213	-350	Revision - 04 : Due to shutdown of 400KV/220KV MADAKKATHARA-ICT-2
14th May 2022 to 19th May 2022	00-24	3300	90	3210	2647	563		
20th May 2022 to 28th May 2022	00-24	3300	90	3210	2589	621		
29th May 2022 to 31st May 2022	00-24	3300	90	3210	2644	566		
Limiting Constraint (any one or	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	iii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for May 2022
Import Capability of S3 for May2022

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor	Quantum of Revision(MW)
0	26-01-2022	01-05-2022 to 31-05-2022	Revision-0	-	
1	29-04-2022	01-05-2022 to 31-05-2022	1.Outages approved in 189th OCC meeting 2.Updated network with May-22 LGBR	S1-->(S2nS3) S3 Import	
2	29-04-2022	01-05-2022 to 31-05-2022	Operationalization of DB power to Tamil Nadu MTOA of 100 MW	S1-->(S2nS3)	
3	01-05-2022	03-05-2022	Revision - 03 : Due to shutdown of 400KV/220KV MADAKKATHARA-ICT-1	Import od S3	-350
4	11-05-2022	13-05-2022	Revision - 04 : Due to shutdown of 400KV/220KV MADAKKATHARA-ICT-2	Import od S3	-350