Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for May 2023

Issue Date: 06/05/2023 Issue Time: 1100 Hrs Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) *	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st May 2023 to 6th	00 - 06 and 18 -24Hrs	8550	450	8100	3821	4279			
May 2023	06 - 18 Hrs	8550	450	8100	3771	4329			
7th May 2023 to 19th	00 - 06 and 18 -24Hrs	8550	450	8100	4071	4029			
May 2023	06 - 18 Hrs	8550	450	8100	4021	4079			
20th May 2023 to 31st	00 - 06 and 18 -24Hrs	8550	450	8100	3996	4104			
May 2023	06 - 18 Hrs	8550	450	8100	3946	4154			
	i. Tripping of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT								
Limiting Constraints (any one or combination thereof)	ii. N-1 violation 2x315 MVA ICTs at 400/230kV Tiruvallam SS								
,	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP iv. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

Natioanl Load Despatch Centre, New Delhi Import Capability of S3 for May 2023

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 6th May 2023	00-24	3500	90	3410	2786	624		
	00-10	3500	90	3410	2665	745		
7th May 2023	10-24	3000	90	2910	2665	245	-500	Due to 220kV Kochi Bus-1 & 2
8th May 2023 to 19th May 2023	00-24	3500	90	3410	2665	745		
20th May 2023 to 31st May 2023	00-24	3500	90	3410	2649	761		
Limiting Constraint	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin ss will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	iii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre Transfer Capability between S1- (S2&S3) for May 202 Import Capability of S3 for May 2023

Revision	Date of	Period of	Reason for Revision				
No Revision		Revision					
0	26-01-2023	01-05-2023	Revision-0				
		to 31-05-2023	Nevision-0				
1	28-04-2023	01-05-2023	1.Upated network and ISGS outages approved in				
1		to 31-05-2023	last OCC meeting				
2	05-05-2023	07-05-2023	2.Due to 220kV Kochi Bus-1 & 2				

Quantum in MW	Corrido r
-	
-	
-500	S3 import