Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for November 2021

Issue Date: 28/07/2021 Issue Time: 1700 Hrs Revision No. 0

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st November 2021 to 30th November 2021	00 - 24	8000	450	7550	3656	3894			
Limiting Constraints (any one or combination thereof)	ii. N-1 violatio	i. N-1 violation 2x315 MVA ICT at 400/230kV Thiruvallam ICT ii. N-1 violation 2x250 MVA ICT at 400/230kV Neyveli stage2 ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

Natioanl Load Despatch Centre, New Delhi Import Capability between S3 for November 2021

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2021 to 30th November 2021	00-24	3350	90	3260	2832	428		
Limiting Constraint	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
(any one or	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre Transfer Capability between S1- (S2&S3) for November 2021 Import Capability between S3 for November 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-07-21	01-11-2021	Revision-0	_
		to 30-11-2021	NEVISIOI1-0	