Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for November 2022

Issue Date: 26/07/2022		Issue Time: 1900 Hrs			Revision No. 0				
Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) *	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st November 2022 to 30th November 2022	00 - 06 and 18 -24 Hrs	8400	450	7950	3733	4217			
	06 - 18 Hrs	8400	450	7950	3963	3987			
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT ii. N-1 violation 2x315 MVA ICTs at 400/230kV Tiruvallam SS								
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP iv. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								
* 50% of Wind export LTA C	onsidered for S	TOA margin							

Natioanl Load Despatch Centre, New Delhi Import Capability of S3 for November 2022

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2022 to 30th November 2022	00-24	3400	90	3310	2812	498		
	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin ss will lead to over-loading of the Other ICT ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT iii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre Transfer Capability between S1- (S2&S3) for November 2022 Import Capability of S3 for November 2022

Revision	Revision Date of Period of D for the construction of D for the constru							
			Reason for Revision	Corridor				
No	Revision	Revision						
0 26-0	26-07-2022	01-11-2022	Revision-0	_				
	20-07-2022	to 30-11-2022	Nevision-0	_				