

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for October 2018

Issue Date: 03/10/2018

Issue Time: 1230 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2018 to 31st October 2018	00 - 24	8047	463	7584	4405	3179		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Hosur - Salem will lead to overloading of the other circuit							
	ii. (n-1) of 765/400kV ICT at Tiruvalum.							
	iii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	v. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for October 2018

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2018 to 2nd October 2018	00-24	3020	92	2928	2710	218		
3rd October 2018	00-07'	3020	92	2928	2710	218		
	07-24	2520		2428		0		
4th October 2018 to 9th October 2018	00-07'	3020	92	2928	2710	218		Revised as the identer is not availing the 230kV Tirunelveli-Edamon D/C Shutdown.
	07-24	3020		2928		218	+500	
10th October 2018 to 31st October 2018	00-24	3020	92	2928	2710	218		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit *							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System							

