

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for October 2019

Issue Date: 19/10/2019

Issue Time: 1040 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2019 to 12th October 2019	00 - 24	9200	490	8710	3530	5180		
13th October 2019	00 - 06	9200	490	8710	3530	5180		
	06 - 24	8800	490	8310	3530	4780		
14th October 2019 to 19th October 2019	00 - 24	9200	490	8710	3530	5180		
20th October 2019	00 - 06	9200	490	8710	3530	5180		
	06 - 24	8800	490	8310	3530	4780	-400	Due to 400kV Thiruvallam - Palavadi D/C Outage for construction of HVDC Raigarh - Pugalur
21st October 2019 to 31st October 2019	00 - 24	9200	490	8710	3530	5180		
Limiting Constraints (any one or combination thereof)	i. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS							
	ii. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	iii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for October 2019

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2019 to 31st October 2019	00-24	2900	90	2810	2761	49		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit *							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for October 2019
Transfer Capability for Import of S3 for October 2019

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-06-2019	01-10-2019 to 31-10-2019	Revision-0	-
1	12-10-2019	13-10-2019	Revision - 1.Due to 400kV Thiruvallam - Palavadi D/C Outage for construction of HVDC Raigarh - Pugalur	S1-(S2&S3)
2	19-10-2019	20-10-2019	Revision - 2.Due to 400kV Thiruvallam - Palavadi D/C Outage for construction of HVDC Raigarh - Pugalur	S1-(S2&S3)