

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for Octoberber 2021

Issue Date: 29/09/2021

Issue Time: 1900 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2021 to 8th October 2021	00 - 24	8700	450	8250	3683	4567		
9th October 2021 to 9th October 2021	00 - 24	8700	450	8250	3600	4650		
10th October 2021 to 14th October 2021	00 - 24	8700	450	8250	3556	4694		
15th October 2021 to 24th October 2021	00 - 24	8700	450	8250	3474	4776		
25th October 2021 to 29th October 2021	00 - 24	8700	450	8250	3556	4694		
30th October 2021 to 31st October 2021	00 - 24	8700	450	8250	3480	4770		
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	ii. N-1 violation 2x315 MVA ICT at 400/230kV Thiruvallam ICT							
	iii. N-1 violation 2x250 MVA ICT at 400/230kV Neyveli stage2 ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

Natioanl Load Despatch Centre, New Delhi
Import Capability between S3 for Octoberber2021

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2021 to 8th October 2021	00-24	3350	90	3260	2674	586		
9th October 2021 to 9th October 2021	00-24	3350	90	3260	2695	565		
10th October 2021 to 14th October 2021	00-24	3350	90	3260	2702	558		
15th October 2021 to 24th October 2021	00-24	3350	90	3260	2685	575		
25th October 2021 to 29th October 2021	00-24	3350	90	3260	2702	558		
30th October 2021 to 31st October 2021	00-24	3350	90	3260	2681	579		
Limiting Constraint (any one or	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

