## Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for September2021

Issue Date: 26/05/2021 Issue Time: 2300 Hrs Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2021 to 30th September 2021	00 - 24	7250	450	6800	3605	3195		
increar)	i. N-1 violation 2x315 MVA ICT at 400/230kV Thiruvallam ICT  ii. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT  iii. N-1 violation 2x250 MVA ICT at 400/230kV Neyveli stage2 ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

## Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for September2021

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Access (LTA)/ Medium Term	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2021 to 30th September 2021	00-24	3350	90	3260	2795	465		
Limiting Constraint	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
(any one or	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

## National Load Despatch Centre Transfer Capability between S1- (S2&S3) for September2021

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-05-21	01-09-2021 to 30-09-2021	Revision-0	-