Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for September 2023

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) *	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st September 2023 to 30st September 2023	00 - 06 and 18 -24Hrs	8550	450	8100	3839	4261			
	06 - 18 Hrs	8550	450	8100	3789	4311			
Limiting Constraints (any one or combination thereof)	i. Tripping of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT								
	ii. N-1 violation 2x315 MVA ICTs at 400/230kV Tiruvallam SS								
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP iv. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

Natioanl Load Despatch Centre, New Delhi Import Capability of S3 for September 2023 Issue Time: 1400 Hrs

Issue Date: 18/07/2023 Issue Time: 1400 Hrs Revision No. 1

15540 Bate: 10/07/20	188de 11116. 1 100 1119						TC VISION 1 TO. 1	
Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2023 to 30st September 2023	00-24	3950	90	3860	2786	1074	450	Revision 1 due to commissioning of 315 MVA 400/220kVKottayam ICT-1 and 500 MVA 400/220kVKochi ICT-3
Limiting Constraint	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
(any one or	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre Import Capability of S3 for September 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-05-2023	01-09-2023 to 30-09-2023	Revision-0	-
1	18-07-2023	01-09-2023 to 30-09-2023	Revision 1 due to commissioning of 315 MVA 400/220kVKottayam ICT-1 and 500 MVA 400/220kVKochi ICT-3	\$3