Import Transfer Capability of Andra Pradesh for Feb-26

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks			
1st to 28th Feb 2026	00 -06Hrs	1-24	5915	268	5647	4516	1131	-	-			
	06 -12Hrs	25-48	4006	268	3738	4516	-	-	-			
1st to 2stil 1 et 2020	12 -18Hrs	49-72	4067	268	3799	4516	-	-	-			
	18 -24Hrs	73-96	4613	268	4345	4516	-	-	-			
Limiting Constraints (any	i. N-1 contigency of 400/220 kV ICT's at Maradam SS											
one or combination	i. N-1 contigency of 400/220 kV ICT's at Narnoor SS											
	ii. N-1 contige	ency of 400/2	20 kV ICT's at V	ii. N-1 contigency of 400/220 kV ICT's at Vemagiri SS								

Import Transfer Capability of Telangana for Feb-26

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks
1st to 28th Feb 2026	00 -24Hrs	1-96	9983	330	9653	7420	2233	-	-
Limiting Constraints (any one or combination ii. N-1 contigency of 400/220 kV 1x200+2x250+2x315 MVA RTPS ICTs									
	iii. N-1 contigo	ency of 400/2	220 kV 1x500+2	x315 MVA Shankara	apalli ICTs				

Import Transfer Capability of Karnataka for Feb-26

Issue Date: 28/02/2025 Issue Time: 18:00 Hrs Revision No.0

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks					
1st to 28th Feb 2026	00 -24Hrs	1-96	3682	340	3342	5376	-	-	-					
Limiting Constraints	i. N-1 contiger	N-1 contigency of 400/220 kV ICT's at UPCL (With 220kV Kemar bus coupler kept in closed condition)												
(any one or combination	ii. N-1 contige	. N-1 contigency of 400/220 kV ICT's at Hassan												
thereof)	iii. N-1 contige	ency of 400/2	220 kV ICT's at N	Velamangala		N-1 contigency of 400/220 kV ICT's at Nelamangala								

Import Transfer Capability of Tamil Nadu for

Issue Date: 28/02/2025 Issue Time: 18:00 Hrs Revision No.0

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks		
1st to 28th Feb 2026	00 -24Hrs	1-96	14050	350	13700	9177	4523	-	-		
Limiting Constraints	i. N-1 contigency of 400/230 kV ICT's at Salem 400 kV SS										
(any one or combination	ii. Tripping of 400kV NCTPS-Manali S/C will cause overloading of 400kV Alamaty-Manali S/C										
thereof)	iii. N-1 contigency of 400/230 kV ICT's at Kalivandapattu 400 kV SS										
thereof)	iv. N-1 contige	iv. N-1 contigency of 400/230 kV ICT's at NLC TS2 and NNTPS									

Import Transfer Capability of Puducherry for

Feb-26

Issue Date: 28/02/2025 Issue Time: 18:00 Hrs Revision No.0

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks	
1st to 28th Feb 2026	00 -24Hrs	1-96	550	10	540	540	-	-	-	
Limiting Constraints	i. Tripping of	Tripping of 400kV NNTPP - Puducherry S/C leads to out overloading of 230kV Pondy-Villanur S/C								
(any one or combination	(any one or combination ii. Tripping of 400kV NNTPP - Puducherry leads to low voltage in Pondy system									