

**Import Transfer Capability of Andhra Pradesh for December 2024**

Issue Date: 29/11/2024

Issue Time: 18:00 Hrs

Revision No.1

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks
1st to 31st Dec 2024	00 -06Hrs	1-24	6336	268	6068	4516	1552	-	R1
	06 -12Hrs	25-48	5417	268	5149	4516	633	-	R1
	12 -18Hrs	49-72	8471	268	8203	4516	3687	-	R1
	18 -24Hrs	73-96	6097	268	5829	4516	1313	-	R1
Limiting Constraints (any one or combination thereof)	i. N-1 contingency of 400/220 kV ICT's at Maradam SS								
	ii. N-1 contingency of 400/220 kV ICT's at Vemagiri SS								

**Import Transfer Capability of Telangana for December 2024**

Issue Date: 29/11/2024

Issue Time: 18:00 Hrs

Revision No.1

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks
1st to 31st Dec 2024	00 -24Hrs	1-96	8328	327	8001	7420	581	-	R1
Limiting Constraints (any one or combination thereof)	i. N-1 contingency of 400kV Maheshwaram(TS)-Maheshwaram(PG)-D/C								
	ii. N-1 contingency of 400/220 kV 1x200+2x250+2x315 MVA RTPS ICTs								
	iii. N-1 contingency of 400/220 kV 1x500+2x315 MVA Warangal ICTs								

### Import Transfer Capability of Karnataka for December 2024

Issue Date: 29/11/2024

Issue Time: 18:00 Hrs

Revision No.1

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks
1st to 31st Dec 2024	00 -24Hrs	1-96	3730	340	3390	5376	-	-	R1
Limiting Constraints (any one or combination thereof)	i. N-1 contingency of 400/220 kV ICT's at Yelahanka								
	ii. N-1 contingency of 400/220 kV ICT's at Nelamangala								
	iii. N-1 contingency of 400/220 kV ICT's at Hassan								
	iv. N-1 contingency of 400/220 kV ICT's at UPCL (With 220kV Kemar bus coupler kept in closed condition)								

### Import Transfer Capability of Tamil Nadu for December 2024

Issue Date: 29/11/2024

Issue Time: 18:00 Hrs

Revision No.1

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks
1st to 31st Dec 2024	00 -24Hrs	1-96	14050	350	13700	9177	4523	-	R1
Limiting Constraints (any one or combination thereof)	i. N-1 contingency of 400/230 kV ICT's at NLC TS2 and NNTPS								
	ii. N-1 contingency of 400/230 kV ICT's at Kalivandapattu 400 kV SS								
	iii. Tripping of 400kV NCTPS-Manali S/C will cause overloading of 400kV Alamaty-Manali S/C								
	iv. N-1 contingency of 400/230 kV ICT's at Salem 400 kV SS								

### Import Transfer Capability of Puducherry for December 2024

Issue Date: 29/11/2024

Issue Time: 18:00 Hrs

Revision No.1

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks
1st to 31st Dec 2024	00 -24Hrs	1-96	550	10	540	540	-	-	R1
Limiting Constraints (any one or combination)	i. Tripping of 400kV NNTPP - Puducherry S/C leads to out overloading of 230kV Pondy-Villanur S/C								
	ii. Tripping of 400kV NNTPP - Puducherry leads to low voltage in Pondy system								