

POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE
NEW DELHI

Date of Reporting: **24-Nov-18**
System Reliability Indices Report for: **23-Nov-18**

Percentage (%) of times ATC was violated

| S.No. | Corridor | Number of Blocks Violated | Number of Hours Violated | %Violation |
|-------|--------------|---------------------------|--------------------------|------------|
| 1 | WR-NR | 0 | 0.00 | 0.00 |
| 2 | ER-NR | 0 | 0.00 | 0.00 |
| 3 | Import of NR | 0 | 0.00 | 0.00 |
| 4 | NEW-SR | 0 | 0.00 | 0.00 |
| 5 | NER Import | 0 | 0.00 | 0.00 |

Percentage(%) of times (N-1) Criteria was violated

| S.No. | Corridor | Number of Blocks Violated | Number of Hours Violated | %Violation |
|-------|--------------|---------------------------|--------------------------|------------|
| 1 | WR-NR | 0 | 0.00 | 0.00 |
| 2 | ER-NR | 0 | 0.00 | 0.00 |
| 3 | Import of NR | 0 | 0.00 | 0.00 |
| 4 | NEW-SR | 0 | 0.00 | 0.00 |
| 4 | NER Import | 0 | 0.00 | 0.00 |

Voltage Profile for the day of 23-Nov-2018

| Region | Station | %age of time Voltage below 728/380 kV | %age of time Voltage between 728/380 kV & 800/420 kV | %age of time Voltage above 800/420 kV | Voltage deviation index (%age of time voltage is outside IEGC band) | Maximum Voltage (kV) | Minimum Voltage (kV) | Average Voltage (kV) |
|------------------|-----------------------------|---------------------------------------|--|---------------------------------------|---|----------------------|----------------------|----------------------|
| NR | Agra | 0.00% | 100.00% | 0.00% | 0.00% | 797 | 769 | 783 |
| | Agra (Fatehabad) | 0.00% | 97.71% | 2.29% | 2.29% | 809 | 764 | 780 |
| | Anpara-C | 0.00% | 100.00% | 0.00% | 0.00% | 770 | 766 | 767 |
| | Anpara-D | 0.00% | 100.00% | 0.00% | 0.00% | 768 | 762 | 765 |
| | Anta | 0.00% | 100.00% | 0.00% | 0.00% | 789 | 770 | 781 |
| | Ballia | 0.00% | 100.00% | 0.00% | 0.00% | 785 | 767 | 775 |
| | Bhiwani | 0.00% | 97.36% | 2.64% | 2.64% | 807 | 776 | 789 |
| | Bareilly | 0.00% | 100.00% | 0.00% | 0.00% | 759 | 752 | 758 |
| | Fatehpur | 0.00% | 100.00% | 0.00% | 0.00% | 775 | 752 | 763 |
| | Greater Noida | 0.00% | 93.96% | 6.04% | 6.04% | 805 | 782 | 793 |
| | Jhatikara | 0.00% | 98.82% | 1.18% | 1.18% | 803 | 773 | 788 |
| | Kanpur GIS | 0.00% | 100.00% | 0.00% | 0.00% | 760 | 754 | 758 |
| | Lucknow | 0.00% | 100.00% | 0.00% | 0.00% | 794 | 773 | 783 |
| | Lalitpur | 0.00% | 100.00% | 0.00% | 0.00% | 798 | 739 | 757 |
| | Meerut | 0.00% | 94.65% | 4.51% | 4.51% | 807 | 774 | 789 |
| | Moga | 0.00% | 100.00% | 0.00% | 0.00% | 799 | 758 | 777 |
| | Phagi | 0.00% | 100.00% | 0.00% | 0.00% | 798 | 768 | 783 |
| Varanasi | 0.00% | 100.00% | 0.00% | 0.00% | 789 | 770 | 779 | |
| Unnao | 0.00% | 100.00% | 0.00% | 0.00% | 773 | 752 | 755 | |
| WR | Akola | 0.00% | 100.00% | 0.00% | 0.00% | 784 | 760 | 773 |
| | Aurangabad | 0.00% | 100.00% | 0.00% | 0.00% | 798 | 773 | 786 |
| | Bhopal (BDTCL) | 0.00% | 100.00% | 0.00% | 0.00% | 786 | 757 | 770 |
| | Bilaspur | 0.00% | 100.00% | 0.00% | 0.00% | 776 | 764 | 770 |
| | Bina | 0.00% | 100.00% | 0.00% | 0.00% | 789 | 768 | 779 |
| | Champa | 0.00% | 99.44% | 0.00% | 0.00% | 800 | 787 | 794 |
| | Dharamjaigarh | 0.00% | 100.00% | 0.00% | 0.00% | 785 | 773 | 779 |
| | Dhule (BDTCL) | 0.00% | 100.00% | 0.00% | 0.00% | 792 | 767 | 781 |
| | Ektuni | 0.00% | 100.00% | 0.00% | 0.00% | 784 | 757 | 772 |
| | Gwalior | 0.00% | 100.00% | 0.00% | 0.00% | 797 | 768 | 784 |
| | Indore | 0.00% | 100.00% | 0.00% | 0.00% | 785 | 754 | 769 |
| | Jabalpur | 0.00% | 100.00% | 0.00% | 0.00% | 796 | 775 | 786 |
| | Koradi | 0.00% | 100.00% | 0.00% | 0.00% | 773 | 756 | 765 |
| | Pune | 0.00% | 99.72% | 0.00% | 0.00% | 800 | 764 | 785 |
| | Raigarh Pooling | 0.00% | 100.00% | 0.00% | 0.00% | 797 | 787 | 792 |
| | Sasan | 0.00% | 100.00% | 0.00% | 0.00% | 772 | 759 | 767 |
| | Satna | 0.00% | 100.00% | 0.00% | 0.00% | 777 | 758 | 769 |
| | Seoni | 0.00% | 100.00% | 0.00% | 0.00% | 794 | 771 | 782 |
| | Sipat | 0.00% | 100.00% | 0.00% | 0.00% | 775 | 764 | 769 |
| | Solapur | 0.00% | 65.97% | 34.03% | 34.03% | 807 | 778 | 795 |
| | Tamnar | 0.00% | 100.00% | 0.00% | 0.00% | 799 | 789 | 794 |
| | Tirora | 0.00% | 100.00% | 0.00% | 0.00% | 767 | 753 | 760 |
| | Vadodara | 0.00% | 100.00% | 0.00% | 0.00% | 790 | 765 | 775 |
| Vindhyachal PS | 0.00% | 100.00% | 0.00% | 0.00% | 775 | 761 | 768 | |
| Wardha | 0.00% | 99.17% | 0.83% | 0.83% | 801 | 777 | 789 | |
| SR | Kurnool | 0.00% | 96.53% | 3.47% | 3.47% | 803 | 756 | 782 |
| | Nellore PS | 0.00% | 100.00% | 0.00% | 0.00% | 797 | 756 | 779 |
| | Raichur | 0.00% | 96.67% | 3.33% | 3.33% | 803 | 764 | 785 |
| | Nizamabad | 0.00% | 86.18% | 13.82% | 13.82% | 810 | 777 | 791 |
| | Srikakulam | 0.00% | 99.93% | 0.07% | 0.07% | 800 | 780 | 789 |
| | Thiruvallur | 0.00% | 87.85% | 12.15% | 12.15% | 803 | 770 | 788 |
| ER | Angul | 0.00% | 100.00% | 0.00% | 0.00% | 783 | 768 | 775 |
| | Gaya | 0.00% | 100.00% | 0.00% | 0.00% | 781 | 765 | 773 |
| | Jharsuguda | 0.00% | 100.00% | 0.00% | 0.00% | 799 | 785 | 792 |
| | Ranchi | 0.00% | 100.00% | 0.00% | 0.00% | 785 | 774 | 779 |
| Sasaram | 0.00% | 100.00% | 0.00% | 0.00% | 763 | 747 | 755 | |
| NER | Azara (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 411 | 402 | 407 |
| | Balipara (400 kV) | 0.00% | 99.72% | 0.28% | 0.28% | 422 | 395 | 408 |
| | Bongaigaon (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 414 | 399 | 408 |
| | Byrnihat (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 411 | 402 | 407 |
| | Palatana (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 415 | 409 | 405 |
| | Misa (400 kV) | 0.00% | 96.88% | 3.13% | 3.13% | 425 | 403 | 412 |
| | Biswanath Chariali (400 kV) | 0.00% | 99.58% | 0.35% | 0.35% | 423 | 394 | 406 |
| Silchar (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 413 | 398 | 406 | |

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.