

POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE
NEW DELHI

Date of Reporting: **26-06-2021**

System Reliability Indices Report for: **25-06-2021**

Percentage (%) of times ATC was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
5	NER Import	0	0.00	0.00

Percentage(%) of times (N-1) Criteria was violated

1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
4	NER Import	0	0.00	0.00

Voltage Profile for the day of 25-06-2021

Region	Station	%age of time Voltage below 728/380 kV	%age of time Voltage between 728/380 kV & 800/420 kV	%age of time Voltage above 800/420 kV	Voltage deviation index (%age of time voltage is outside IEGC band)	Maximum Voltage (kV)	Minimum Voltage (kV)	Average Voltage (kV)
NR	Agra	0.00%	100.00%	0.00%	0.00%	793	761	777
	Agra (Fatehabad)	0.00%	100.00%	0.00%	0.00%	793	761	777
	Anpara-C	0.00%	100.00%	0.00%	0.00%	767	757	762
	Anpara-D	0.00%	100.00%	0.00%	0.00%	767	757	762
	Anta	0.00%	100.00%	0.00%	0.00%	794	771	784
	Ballia	0.00%	100.00%	0.00%	0.00%	781	756	767
	Bara	0.00%	100.00%	0.00%	0.00%	786	763	769
	Bhiwani	0.00%	100.00%	0.00%	0.00%	793	753	777
	Bareilly	0.00%	100.00%	0.00%	0.00%	792	754	775
	Fatehpur	0.00%	100.00%	0.00%	0.00%	785	752	770
	Greater Noida	0.00%	100.00%	0.00%	0.00%	800	756	778
	Jhatikara	0.00%	100.00%	0.00%	0.00%	792	751	773
	Kanpur GIS	0.00%	100.00%	0.00%	0.00%	789	761	774
	Lucknow	0.00%	100.00%	0.00%	0.00%	787	758	771
	Lalitpur	0.00%	100.00%	0.00%	0.00%	784	763	774
	Meehut	0.00%	100.00%	0.00%	0.00%	797	751	776
	Moga	0.00%	100.00%	0.00%	0.00%	796	754	778
Phagi	0.00%	100.00%	0.00%	0.00%	799	762	782	
Varanasi	0.00%	100.00%	0.00%	0.00%	786	766	775	
WR	Akola	0.00%	100.00%	0.00%	0.00%	783	754	770
	Aurangabad	0.00%	100.00%	0.00%	0.00%	795	772	783
	Bhopal (BDTCL)	0.00%	100.00%	0.00%	0.00%	787	771	779
	Bilaspur	0.00%	100.00%	0.00%	0.00%	783	770	776
	Bina	0.00%	100.00%	0.00%	0.00%	792	771	783
	Champa	0.00%	100.00%	0.00%	0.00%	796	778	788
	Dharamaiagarh	0.00%	100.00%	0.00%	0.00%	784	769	777
	Dhule (BDTCL)	0.00%	100.00%	0.00%	0.00%	782	757	771
	Ektuni	0.00%	100.00%	0.00%	0.00%	782	757	773
	Gwalior	0.00%	100.00%	0.00%	0.00%	798	767	783
	Indore	0.00%	100.00%	0.00%	0.00%	783	766	774
	Jabalpur	0.00%	100.00%	0.00%	0.00%	796	778	788
	Koradi	0.00%	100.00%	0.00%	0.00%	770	751	761
	Pune	0.00%	100.00%	0.00%	0.00%	800	771	787
	Raigarh Pooling	0.00%	100.00%	0.00%	0.00%	794	777	788
	Raipur Pooling	0.00%	100.00%	0.00%	0.00%	792	775	786
	Sasan	0.00%	100.00%	0.00%	0.00%	785	773	780
	Satna	0.00%	100.00%	0.00%	0.00%	793	776	784
	Seoni	0.00%	100.00%	0.00%	0.00%	791	771	781
	Sipat	0.00%	100.00%	0.00%	0.00%	781	776	778
	Solapur	0.00%	97.36%	2.64%	2.64%	802	753	787
	Tamnar	0.00%	100.00%	0.00%	0.00%	796	781	790
	Tirora	0.00%	100.00%	0.00%	0.00%	768	754	761
	Vadodara	0.00%	100.00%	0.00%	0.00%	790	771	780
Vindhyachal PS	0.00%	100.00%	0.00%	0.00%	790	771	781	
Wardha	0.00%	100.00%	0.00%	0.00%	790	771	786	
SR	Kurnool	0.00%	100.00%	0.00%	0.00%	795	751	777
	Nellore PS	0.00%	100.00%	0.00%	0.00%	788	751	773
	Raichur	0.00%	100.00%	0.00%	0.00%	799	757	781
	Nizamabad	0.00%	100.00%	0.00%	0.00%	794	774	785
	Srikakulam	0.00%	100.00%	0.00%	0.00%	799	776	789
	Thiruvallam	0.00%	100.00%	0.00%	0.00%	799	776	789
	Vemagiri	0.00%	97.71%	2.29%	2.29%	803	769	787
ER	Angul	0.00%	100.00%	0.00%	0.00%	794	779	787
	Gaya	0.00%	100.00%	0.00%	0.00%	776	756	765
	Jharsuguda	0.00%	97.92%	2.08%	2.08%	801	786	794
	Ranchi	0.00%	100.00%	0.00%	0.00%	783	767	776
	Sasaram	0.00%	100.00%	0.00%	0.00%	777	760	769
NER	Ballpara (400 kV)	0.00%	100.00%	0.00%	0.00%	408	397	403
	Bongaigaon (400 kV)	0.00%	100.00%	0.00%	0.00%	410	404	408
	Bongaigaon TPS (400 kV)	0.00%	100.00%	0.00%	0.00%	415	406	411
	Palatana (400 kV)	0.00%	100.00%	0.00%	0.00%	410	403	407
	Misa (400 kV)	0.00%	100.00%	0.00%	0.00%	408	398	404
	Ranganadi (400 kV)	0.00%	100.00%	0.00%	0.00%	416	406	411
	Biswanath Chariali (400 kV)	0.00%	100.00%	0.00%	0.00%	411	399	405
Silchar (400 kV)	0.00%	100.00%	0.00%	0.00%	412	405	409	

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.