

POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE
NEW DELHI

Date of Reporting: 29-Feb-20
System Reliability Indices Report for: 28-Feb-20

Percentage (%) of times ATC was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	1	0.25	1.04
5	NER Import	0	0.00	0.00

Percentage(%) of times (N-1) Criteria was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
4	NER Import	0	0.00	0.00

Voltage Profile for the day of 28-Feb-2020

Region	Station	%age of time Voltage below 728/380 kV	%age of time Voltage between 728/380 kV & 800/420 kV	%age of time Voltage above 800/420 kV	Voltage deviation index (%age of time voltage is outside IEGC band)	
NR	Agra	0.00%	100.00%	0.00%	0.00%	
	Agra (Fatehabad)	0.00%	100.00%	0.00%	0.00%	
	Anpara-C	0.00%	100.00%	0.00%	0.00%	
	Anpara-D	0.00%	100.00%	0.00%	0.00%	
	Anta	0.00%	100.00%	0.00%	0.00%	
	Ballia	0.00%	100.00%	0.00%	0.00%	
	Bara	0.00%	100.00%	0.00%	0.00%	
	Bhiwani	0.00%	90.56%	9.44%	9.44%	
	Fatehpur	0.00%	100.00%	0.00%	0.00%	
	Jhatikara	0.00%	100.00%	0.00%	0.00%	
	Kanpur GIS	0.00%	100.00%	0.00%	0.00%	
	Lucknow	0.00%	84.38%	15.63%	15.63%	
	Lalitpur	0.00%	100.00%	0.00%	0.00%	
	Meerut	0.00%	99.31%	0.69%	0.69%	
	Phagi	0.00%	100.00%	0.00%	0.00%	
Varanasi	0.00%	100.00%	0.00%	0.00%		
Unnao	0.00%	100.00%	0.00%	0.00%		
WR	Akola	0.00%	100.00%	0.00%	0.00%	
	Aurangabad	0.00%	99.72%	0.28%	0.28%	
	Bhopal (BDTCL)	0.00%	100.00%	0.00%	0.00%	
	Bilaspur	0.00%	100.00%	0.00%	0.00%	
	Bina	0.00%	100.00%	0.00%	0.00%	
	Champa	0.00%	100.00%	0.00%	0.00%	
	Gwalior	0.00%	100.00%	0.00%	0.00%	
	Indore	0.00%	100.00%	0.00%	0.00%	
	Koradi	0.00%	100.00%	0.00%	0.00%	
	Pune	0.00%	100.00%	0.00%	0.00%	
	Raigarh Pooling	0.00%	100.00%	0.00%	0.00%	
	Sasan	0.00%	100.00%	0.00%	0.00%	
	Satna	0.00%	100.00%	0.00%	0.00%	
	Seoni	0.00%	100.00%	0.00%	0.00%	
	Sipat	0.00%	100.00%	0.00%	0.00%	
	Solapur	0.00%	99.38%	0.63%	0.63%	
	Tamnar	0.00%	100.00%	0.00%	0.00%	
	Tirora	0.00%	100.00%	0.00%	0.00%	
	Kurnool	0.00%	99.72%	0.28%	0.28%	
	SR	Nellore PS	0.00%	100.00%	0.00%	0.00%
Raichur		0.00%	100.00%	0.00%	0.00%	
Nizamabad		0.00%	94.65%	5.35%	5.35%	
Srikakulam		0.00%	98.54%	1.46%	1.46%	
Thiruvallam		0.00%	98.54%	1.46%	1.46%	
Vemagiri		0.00%	98.13%	1.88%	1.88%	
ER		Angul	0.00%	100.00%	0.00%	0.00%
		Gaya	0.00%	100.00%	0.00%	0.00%
		Jharsuguda	0.00%	100.00%	0.00%	0.00%
		Ranchi	0.00%	100.00%	0.00%	0.00%
	Balipara (400 kV)	0.00%	100.00%	0.00%	0.00%	
NER	Bongaigaon (400 kV)	0.00%	100.00%	0.00%	0.00%	
	Palatana (400 kV)	0.00%	58.75%	41.25%	41.25%	
	Misa (400 kV)	0.00%	63.19%	36.81%	36.81%	
	Biswanath Chariali (400 kV)	0.00%	100.00%	0.00%	0.00%	
	Silchar (400 kV)	0.00%	58.89%	41.11%	41.11%	

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.