

National Load Despatch Centre
Import of Tripura Transfer Capability for October 2021

Issue Date: 28th Sep 2021

Issue Time: 2000 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Oct 2021 to 31st Oct 2021	00 - 18	275	6	269	0	269	-	
	18- 22	220	6	214	0	214	-	
	22 - 24	275	6	269	0	269	-	

Limiting Constraints

N-1 of 132 kV of Palatana-Surajmaninagar S/C and limiting element observed is 132 kV SM-Nagar (TR) -SM Nagar(ISTS) S/C