

**Natioanl Load Despatch Centre
Transfer Capability between India and Bangladesh for August 2014**

Issue Date: 28/08/2014

Issue Time: 1800 hrs

Revision No. 3

Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2014 to 2nd August 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
3rd August 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	450		450	330	120		
4th August 2014 to 9th August 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
10th August 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	450		450	330	120		
11th August 2014 to 14th August 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
15th August 2014 to 16th August 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	500		500	330	170		
17th August 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	500		500	330	170		
18th August 2014	0000-0900	500	0	500	330	170		
	0900-1030	250		250	330	0		
	1030 - 1530	250		250	330	0		
	1530-1730	475		475	330	145		
	1730 -2400	425		425	330	95		
19th August 2014 to 23rd August 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
24th August 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	450		450	330	120		
25st August 2014 to 28th August 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
29th August 2014 to 30th August 2014	0000-0630	500	0	500	330	170		Revised due to shutdown of Bheramara BTB HVDC.
	0630 - 1030	0		0	330	0	-500	
	1030 - 1730	0		0	330	0	-475	
	1730 -1900	0		0	330	0	-425	
	1900 -2400	425		425	330	95		
31st August 2014	0000-0630	500	0	500	330	170		
	0630-1030	0		0	330	0	-500	
	1030 - 1600	0		0	330	0	-500	
	1600 - 1730	500		500	330	170		
	1730 -2400	450		450	330	120		

Monday to Saturday	
Time Period	Limiting Constraints
0000-1030	---
1030-1730	High loading of 400 kV Farakkka -Behrampur S/C and low voltage at Jeerat
1730-2400	

Sundays	
Time Period	Limiting Constraints
0000-1030	---
1030-1730	High loading of 400 kV Farakkka -Behrampur S/C and low voltage at Jeerat
1730-2400	

**National Load Despatch Centre
Total Transfer Capability for August 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	13-08-2014	15/08/14 - 17/08/14	Revised considering anticipated low demand of West Bengal in view of Independence Day and long weekend.
2	17-08-2014	18-08-2014	Revised due to the shutdown of 400 kV Farakka-Behrapore S/C.
3	28-08-2014	29/08/14 - 31/08/14	Revised due to shutdown of Bheramara BTB HVDC.