

National Load Despatch Centre, New Delhi
Transfer Capability between India and Bangladesh for August 2020

Issue Date: 28th April 2020

Issue Time: 1800 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | TTC from India to Bangladesh from Indian Side* | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Limiting constraint | Comments |
|-------------------------------------|--------------------------|--|--------------------|-------------------------------------|--|--|-------------------------------------|---|----------|
| 1st August 2020 to 31st August 2020 | 0000-0630 | 1000 | 0 | 1000 | 760 | 240 | | Under N-1 of 400 kV Berhampore Bheramara, voltage at Berhampore tends to dip. | |
| | 0630-2330 | 1000 | | 1000 | 760 | 240 | | | |
| | 2330-2400 | 1000 | | 1000 | 760 | 240 | | | |

| | |
|---------|---|
| Note 1: | In case of operation of SPS, Transfer Capability will be revised accordingly. |
| Note 2: | Schedule between India and Bangladesh will be prepared using the above table till the next revision |
| Note 3: | Transfer Capability between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side. |
| Note 4: | LTA of Bangladesh is considered as 300 MW from DVC, 250 MW from Sembcorp Energy India Limited and 210 MW from ISGS allocation (excluding auxiliaries+losses). |

National Load Despatch Centre
Transfer Capability between India and Bangladesh for August 2020

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |