

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between India and Bangladesh for March 2015

Issue Date: 16/03/2015

Issue Time: 1040 hrs

Revision No. 1

Date	Time Period in IST (hrs)	TTC from India to Bangladesh from Indian Side*	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
1st March 2015 to 31st March 2015	0000-0630	500	0	500	460	40		No constraints from Indian Side.	
	0630-2330	500		500	460	40			
	2330-2400	500		500	460	40			

1. NLDC Bangladesh vide Memo no LDC/PGCB/35/2015/114 issued on 15th March 2015, has advised the following limits of power flow through HVDC Bheramara

S. No.	Date & Time	BST	IST	Quantum of Power (MW)
1	17th March 2015 onwards	00:30 to 07:00	00:00 to 06:30	500
		07:00 to 24:00	06:30 to 23:30	500
		00:00 to 00:30	23:30 to 00:00	500

Note 1:	There is no limitation on the flow on HVDC Bheramera from the Indian side during normal conditions.
Note 2:	In case of operation of SPS, Transfer Capability will be revised accordingly.
Note 3:	Schedule between India and Bangladesh for January 2015 will be prepared using the above table till the next revision
Note 4:	Transfer Capabiliy between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.

**National Load Despatch Centre
Total Transfer Capability for March 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	16-03-2015	17/03/2015 onwards till further instruction	NLDC Bangladesh vide Memo no LDC/PGCB/35/2015/114 issued on 15th March 2015, has given revised dispatching instructions