

Natioanl Load Despatch Centre
Transfer Capability between India and Bangladesh for November 2014

Issue Date: 7/11/2014

Issue Time: 1600 hrs

Revision No. 1

Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2014 to 6th November 2014	0000-1030	500	0	500	460	40		
	1030 - 1730	500		500	460	40		
	1730-1800	500		500	460	40		
	1800-2400	500		500	460	40		
7th November 2014	0000-1030	500	0	500	460	40		Revised due to low generation at Bakreshwar.
	1030 - 1700	500		500	460	40		
	1700-2400	350		350	460	0	-150	
8th November 2014 to 30th November 2014	0000-1030	500	0	500	460	40		
	1030 - 1730	500		500	460	40		
	1730-1800	500		500	460	40		
	1800-2400	500		500	460	40		

1st Nov'14 to 30th Nov'14	
Time Period	Limiting Constraints
0000-1700	
1700-2200	
2200-2400	

Note: In case of operation of SPS, Transfer Capability will be revised accordingly.

**National Load Despatch Centre
Total Transfer Capability for November 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	07-11-2014	07-11-2014	Revised due to low generation at Bakreshwar