

Natioanl Load Despatch Centre
Transfer Capability between India and Bangladesh for November 2014

Issue Date: 9/11/2014

Issue Time: 1700 hrs

Revision No. 2

Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2014 to 6th November 2014	0000-1030	500	0	500	460	40		
	1030 - 1730	500		500	460	40		
	1730-1800	500		500	460	40		
	1800-2400	500		500	460	40		
7th November 2014	0000-1030	500	0	500	460	40		
	1030 - 1700	500		500	460	40		
	1700-2400	350		350	460	0		
8th November 2014 to 9th November 2014	0000-1030	500	0	500	460	40		
	1030 - 1730	500		500	460	40		
	1730-1800	500		500	460	40		
	1800-2400	500		500	460	40		
10th November 2014 to 30th November 2014	0000-1030	250	0	250	460	0	-250	As per the communication received from NLDC Bangladesh, power flow during Off-Peak hours has been revised.
	1030 - 1630	250		250	460	0	-250	
	1630-2130	500		500	460	40		
	2130-2400	250		250	460	0	-250	

1st Nov'14 to 30th Nov'14	
Time Period	Limiting Constraints
0000-1700	
1700-2200	
2200-2400	

Note: In case of operation of SPS, Transfer Capability will be revised accordingly.

NLDC Bangladesh has vide Memo no LDC/PGCB/35/2014/463 and earlier email on 7th Nov 2014 has advised the following limits of power flow through HVDC Bheramara

S. No.	BST	IST	Quantum of Power (MW)
1	00:00 to 17:00	23:30 to 16:30	250
2	17:00 to 22:00	16:30 to 21:30	500
3	22:00 to 24:00	21:30 to 23:30	250

**National Load Despatch Centre
Total Transfer Capability for November 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	07-11-2014	07-11-2014	Revised due to low generation at Bakreshwar
2	08-11-2014	10/11/14 to 30/11/2014	As per the communication received from NLDC Bangladesh, power flow during Off-Peak hours has been revised.