

**Natioanl Load Despatch Centre
Transfer Capability between India and Bangladesh for October 2014**

Issue Date: 1/10/2014

Issue Time: 1300 hrs

Revision No. 0

| Date | Time Period (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|--|-------------------|---------------------------------|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st October 2014 | 0000-1030 | 500 | 0 | 500 | 330 | 170 | | |
| | 1030 - 1730 | 475 | | 475 | 330 | 145 | | |
| | 1730-1800 | 425 | | 425 | 330 | 95 | | |
| | 1800-2400 | 330 | | 330 | 330 | 0 | | |
| 2nd October to 7th October 2014 | 0000-1800 | 500 | 0 | 500 | 330 | 170 | | |
| | 1800 - 2400 | 450 | | 450 | 330 | 120 | | |
| 8th October 2014 to 11th October 2014 | 0000-1030 | 500 | 0 | 500 | 330 | 170 | | |
| | 1030 - 1730 | 475 | | 475 | 330 | 145 | | |
| | 1730-1800 | 425 | | 425 | 330 | 95 | | |
| | 1800-2400 | 330 | | 330 | 330 | 0 | | |
| 12th October 2014 | 0000-1030 | 500 | 0 | 500 | 330 | 170 | | |
| | 1030 - 1730 | 500 | | 500 | 330 | 170 | | |
| | 1730 -2400 | 450 | | 450 | 330 | 120 | | |
| 13th October 2014 to 18th October 2014 | 0000-1030 | 500 | 0 | 500 | 330 | 170 | | |
| | 1030 - 1730 | 475 | | 475 | 330 | 145 | | |
| | 1730-1800 | 425 | | 425 | 330 | 95 | | |
| | 1800-2400 | 330 | | 330 | 330 | 0 | | |
| 19th October 2014 | 0000-1030 | 500 | 0 | 500 | 330 | 170 | | |
| | 1030 - 1730 | 500 | | 500 | 330 | 170 | | |
| | 1730 -2400 | 450 | | 450 | 330 | 120 | | |
| 20th October 2014 to 25th October 2014 | 0000-1030 | 500 | 0 | 500 | 330 | 170 | | |
| | 1030 - 1730 | 475 | | 475 | 330 | 145 | | |
| | 1730-1800 | 425 | | 425 | 330 | 95 | | |
| | 1800-2400 | 330 | | 330 | 330 | 0 | | |
| 26th October 2014 | 0000-1030 | 500 | 0 | 500 | 330 | 170 | | |
| | 1030 - 1730 | 500 | | 500 | 330 | 170 | | |
| | 1730 -2400 | 450 | | 450 | 330 | 120 | | |
| 27th October 2014 to 31st October 2014 | 0000-1030 | 500 | 0 | 500 | 330 | 170 | | |
| | 1030 - 1730 | 475 | | 475 | 330 | 145 | | |
| | 1730-1800 | 425 | | 425 | 330 | 95 | | |
| | 1800-2400 | 330 | | 330 | 330 | 0 | | |

Monday to Saturday

| Time Period | Limiting Constraints |
|-------------|--|
| 0000-1030 | --- |
| 1030-1730 | High loading of 400 kV Farakkka -Behrampur S/C and low voltage at Jeerat |
| 1730-2400 | |

Sundays

| Time Period | Limiting Constraints |
|-------------|----------------------|
| 0000-1030 | --- |
| 1030-1730 | |
| 1730-2400 | |

**National Load Despatch Centre
Total Transfer Capability for October 2014**

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |
| | | | |
| | | | |