

Natioanl Load Despatch Centre
Transfer Capability between India and Bangladesh for October 2014

Issue Date: 20/10/2014

Issue Time: 2000 hrs

Revision No. 4

Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730-1800	425		425	330	95		
	1800-2400	330		330	330	0		
2nd October 2014 to 7th October 2014	0000-1800	500	0	500	330	170		
	1800 - 2400	450		450	330	120		
8th October 2014 to 11th October 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730-1800	425		425	330	95		
	1800-2400	330		330	330	0		
12th October 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	450		450	330	120		
13th October 2014 to 14th October 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730-1800	425		425	330	95		
	1800-2400	330		330	330	0		
15th October 2014	0000-1030	500	0	500	460	40		
	1030 - 1730	500		500	460	40		
	1730-1800	500		500	460	40		
	1800-2400	500		500	460	40		
16th October 2014	0000-0630	500	0	500	460	40		
	0630 - 1200	210		210	460	0		
	1200-1800	500		500	460	40		
	1800-2400	350		350	460	0		
17th October 2014 to 20th October 2014	0000-1030	500	0	500	460	40		
	1030 - 1730	500		500	460	40		
	1730-1800	500		500	460	40		
	1800-2400	350		350	460	0		
21st October 2014 to 22nd October 2014	0000-1730	500	0	500	460	40		In view of lower generation at KTHPP and higher demand in Jeerat/Subhasgram
1730-2400	400	400	460	0	-100			
23rd October 2014	0000-2400	500	0	500	460	40		
24th October 2014 to 25th October 2014	0000-1730	500	0	500	460	40		In view of lower generation at KTHPP and higher demand in Jeerat/Subhasgram
	1730-2400	400	400	460	0	-100		
26th October 2014	0000-2400	500	0	500	460	40		
	0000-1730	500	0	500	460	40		In view of lower generation at KTHPP and higher demand in Jeerat/Subhasgram
1730-2400	400	400	460	0	-100			
28th October 2014 to 31st October 2014	0000-1030	500	0	500	460	40		
	1030 - 1730	500		500	460	40		
	1730-1800	500		500	460	40		
	1800-2400	500		500	460	40		

Monday to Saturday	
Time Period	Limiting Constraints
0000-1030	---
1030-1730	High loading of 400 kV Farakkka -Behrampur S/C and low voltage at Jeerat
1730-2400	

Sundays	
Time Period	Limiting Constraints
0000-1030	---
1030-1730	High loading of 400 kV Farakkka -Behrampur S/C and low voltage at Jeerat
1730-2400	

15th Oct'14 to 31st Oct'14	
Time Period	Limiting Constraints
0000-1030	---
1030-1730	
1730-2400	

Note: In case of operation of SPS, Transfer Capability will be revised accordingly.

**National Load Despatch Centre
Total Transfer Capability for October 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	13.10.2014	15.10.2014 to 31.10.2014	Revised due following reasons: (1)Anticipated reduction in West Bengal demand. (2)LTA revised from 230 MW to 210 MW based on the ISGS. generation from last two weeks. (3)MTOA revised based on addl. Grant of 150MW from West Bengal.
2	15.10.2014	16.10.2014	Revised due to shut down of 400 KV Farakka-Behrampur S/C.
3	10/16/2014	17-10-2014 to 20-10-2014	Revised keeping in view the SPS operation of HVDC Bheramera
4	20.10.2014	21.10.2014 to 27.10.2014	Revised keeping in view of lower generation at KTPP and higher demand in Jeerat/Subhasgram