

National Load Despatch Centre, New Delhi
Transfer Capability between India and Bangladesh for October 2018

Issue Date: 28th June 2018

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	TTC from India to Bangladesh from Indian Side*	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
1st October 18 to 31st October 18	0000-0630	500	0	500	250	250		No constraints from Indian Side	
	0630-2330	500		500	250	250			
	2330-2400	500		500	250	250			

Note 1:	There is no limitation on the flow on HVDC Bheramara from the Indian side during normal conditions.
Note 2:	In case of operation of SPS, Transfer Capability will be revised accordingly.
Note 3:	Schedule between India and Bangladesh will be prepared using the above table till the next revision
Note 4:	Transfer Capability between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.
Note 5:	LTA of Bangladesh is considered as 210 MW (excluding auxiliaries+losses) and MTOA is 40 MW

National Load Despatch Centre, New Delhi
Transfer Capability between India and Bangladesh for October 2018

Revision No	Date of Revision	Period of Revision	Reason for Revision