

**Natioanl Load Despatch Centre**  
**Transfer Capability between India and Bangladesh for September 2014**

Issue Date: 13/09/2014

Issue Time: 2220 hrs

Revision No. 2

Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2014 to 6th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
7th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	450		450	330	120		
8th September 2014 to 9th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
10th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 - 1800	425		425	330	95		
	1800 -2200	330		330	330	0		
	2200 -2400	380		380	330	50		
11th September 2014 to 13th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -1800	425		425	330	95		
	1800 -2200	330		330	330	0		
	2200 -2400	380		380	330	50		
14th September 2014	0000-0600	500	0	500	330	170		Revised due to shutdown of 400 kV Bakreswar - Jeerat
	0600-1030	425		425	330	95	-75	
	1030 - 1500	425		425	330	95	-75	
	1500 - 1730	500		500	330	170		
	1730 -2200	450		450	330	120		
	2200 -2400	450		450	330	120		
15th September 2014 to 20th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730-1800	425		425	330	95		
	1800 -2200	330		330	330	0		
	2200 -2400	380		380	330	50		
21st September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2200	450		450	330	120		
	2200 -2400	450		450	330	120		
22nd September 2014 to 27th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730-1800	425		425	330	95		
	1800 -2200	330		330	330	0		
	2200 -2400	380		380	330	50		
28th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2200	450		450	330	120		
	2200 -2400	450		450	330	120		
29th September 2014 to 30th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730-1800	425		425	330	95		
	1800 -2200	330		330	330	0		
	2200 -2400	380		380	330	50		

Monday to Saturday	
Time Period	Limiting Constraints
0000-1030	---
1030-1730	
1730-1800	High loading of 400 kV Farakkka -Behrampur S/C and low voltage at Jeerat
1800-2400	

Sundays	
Time Period	Limiting Constraints
0000-1030	---
1030-1730	
1730-2400	High loading of 400 kV Farakkka -Behrampur S/C and low voltage at Jeerat

**National Load Despatch Centre  
Total Transfer Capability for September 2014**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	10-09-2014	10-09-2014	Revised due to low generation at Kolaghat and high line loading on 400 kV Farakka -Behrampur S/C
		11-09-2014 to 13-09-2014	
		15-09-2014 to 20-09-2014	
		22-09-2014 to 27-09-2014	
		29-09-2014 to 30-09-2014	
2	13-09-2014	14-09-2014	Revised due to shutdown of 400 kV Bakreswar - Jeerat