

National/\_\_\_\_\_Regional Load Despatch Centre

Notice Number: (NLDC/RLDC)/<sup>2016/09/02</sup>yyyy/mm/... Date: <sup>08/09/16</sup>dd/mm/yy  
 To SR LDC Time of Issue: <sup>06:54</sup>hh:mm

**WARNING NOTICE**

The actual transfer of electricity on following corridors has crossed the ATC.

Corridor/Control Area	ATC (MW)	Actual Flow (MW)
<u>SR Import</u>	<u>3900</u>	<u>6574</u>

The following regional entities, which are downstream of the congested corridor, are advised to reduce their drawl/increase their generation to decongest the system:

- 1. All entities of SR
- ...
- m.

The following regional entities, which are upstream of the congested corridor are advised to / increase their drawl/reduce their generation to decongest the system:

- 1. \_\_\_\_\_
- ...
- n.

*f. Laxmi*  
**Shift Charge Manager**

This is a warning notice before levying of congestion charges and issued in accordance with the Central Electricity Regulatory Commission (Measures to relieve congestion in real time operation) Regulations, 2009

NLDC would send this notice to RLDC and RLDC would send this notice to regional entities

Note: Format may be changed as per requirement with prior approval of the Commission.