

National Load Despatch Centre
Import of West Bengal Transfer Capability for January 2022

Issue Date: 26th December 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2022 to 31st January 2022	00-24	5481	450	5031	2721.51	2309		
Limiting Constraints		Tripping of 400 kV Jeerat-Subhasgram causing Thermal loading violation of 220 kV Jeerat-Barasat D/C 214.2 MW and bus voltage violation at Subhasgram 400 KV upto 379.4 KV						