

**National Load Despatch Centre**  
**Import of West Bengal Transfer Capability for November 2021**

Issue Date: 26th October 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2021 to 30th November 2021	00-24	5160	450	4710	2721	1989		
<b>Limiting Constraints</b>		Tripping of 400 kV Jeerat-Subhasgram causing Thermal loading violation of 220 kV Jeerat-Barasat D/C 219.3 MW						