

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Feb 2022

Issue Date: 26th Nov 2021

Issue Time: 1800 hrs

Revision No. 1

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-------------------------------|--------------------------|--|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st Feb 2022 to 28th Feb 2022 | 00-24 | 2590 | 50 | 2540 | 3437.61 | -898 | | |
| Limiting Constraints | | N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs | | | | | | |

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Feb 2022

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |

National Load Despatch Centre
Import of Goa Transfer Capability for Feb 2022

Issue Date: 26th Nov 2021

Issue Time: 1800 hrs

Revision No. 1

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-------------------------------|--|--|---------------------------|--|---|---|--|-----------------|
| 1st Feb 2022 to 28th Feb 2022 | 00-24 | 710 | 15 | 695 | 588 | 107 | | |
| Limiting Constraints | N-1 contingency of 220 kV Mapusa-Ponda-S/C & subsequent 220 kV & 110 kV voltages in Goa system are at the verge of 0.9 pu. | | | | | | | |

National Load Despatch Centre
Import of Goa Transfer Capability for Feb 2022

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |

National Load Despatch Centre
Import of Gujarat Transfer Capability for Feb 2022

Issue Date: 26th Nov 2021

Issue Time: 1800 hrs

Revision No. 1

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-------------------------------|--------------------------|--|--------------------|-------------------------------------|--|--|-------------------------------------|---|
| With SSP Generation | | | | | | | | |
| 1st Feb 2022 to 28th Feb 2022 | 00-09 | 10230 | 330 | 9900 | 8863.516 | 1036.484 | | https://www.slcdguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf |
| 1st Feb 2022 to 28th Feb 2022 | Sep-17 | 9830 | 330 | 9500 | 8863.516 | 636.484 | | |
| 1st Feb 2022 to 28th Feb 2022 | 17-24 | 10230 | 330 | 9900 | 8863.516 | 1036.484 | | |
| Without SSP Generation | | | | | | | | |
| 1st Feb 2022 to 28th Feb 2022 | 00-09 | 10030 | 330 | 9700 | 8863.516 | 836.484 | | https://www.slcdguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf |
| 1st Feb 2022 to 28th Feb 2022 | Sep-17 | 9630 | 330 | 9300 | 8863.516 | 436.484 | | |
| 1st Feb 2022 to 28th Feb 2022 | 17-24 | 10030 | 330 | 9700 | 8863.516 | 836.484 | | |
| Limiting Constraints | | 1) N-1 contingency of 400 kV D/C Banaskantha – Veloda line. 2) N-1 contingency of 765/400 kV Vadodara ICTs 3) N-1 contingency of 400 kV D/C Kala – Kudus line | | | | | | |

National Load Despatch Centre
Import of Gujarat Transfer Capability for Feb 2022

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for Feb 2022

Issue Date: 26th Nov 2021

Issue Time: 1800 hrs

Revision No. 1

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|--------------------------------|---------------------------------|--|---------------------------|--|---|---|--|---|
| *1st Feb 2022 to 28th Feb 2022 | 00-24 | 11091 | 340 | 10751 | 10021 | 730 | | Link:- https://www.sldcmpindia.com/page.php?id=20 |
| Limiting Constraints | | | | | | | | |

* TTC/ATC as declared by SLDC MP in website (Not available for Dec 2021. Hence, Dec'21 TTC/ATC only considered for Mar'22 month also)

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for Dec 2021

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |

National Load Despatch Centre
Import of Maharashtra Transfer Capability for Feb 2022

Issue Date: 26th Nov 2021

Issue Time: 1800 hrs

Revision No. 1

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-------------------------------|------------------------------------|--|---------------------------|--|---|---|--|-----------------|
| 1st Feb 2022 to 28th Feb 2022 | 00-24 | 10060 | 300 | 9760 | 9395.62 | 364 | | |
| Limiting Constraints | N-1 of 400 kV Parli-PG-Parli-MH-DC | | | | | | | |

National Load Despatch Centre
Import of Maharashtra Transfer Capability for Feb 2022

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |