

**National Load Despatch Centre**  
**Import of Chhattisgarh Transfer Capability for Feb 2023**

Issue Date: 26th Oct 2022

Issue Time: 1700 hrs

Revision No. 0

| Date                          | Time Period in IST (hrs) | Total Transfer Capability (TTC)  | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-------------------------------|--------------------------|--|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st Feb 2023 to 28th Feb 2023 | 00-24                    | 2590   | 50                 | 2540                                | 3451.41  | 0  |                                     |          |
| <b>Limiting Constraints</b>   |                          | N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs |                    |                                     |  |  |                                     |          |

**National Load Despatch Centre**  
**Import of Chhattisgarh Transfer Capability for Feb 2023**

| <b>Revision No</b> | <b>Date of Revision</b> | <b>Period of Revision</b> | <b>Reason for Revision</b> |
|--------------------|-------------------------|---------------------------|----------------------------|
|                    |                         |                           |                            |

**National Load Despatch Centre**  
**Import of Daman & Diu Transfer Capability for Feb 2023**

Issue Date: 26th Oct 2022

Issue Time: 1700 hrs

Revision No. 0

| Date                          | Time Period in IST (hrs) | Total Transfer Capability (TTC)                           | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-------------------------------|--------------------------|---|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st Feb 2023 to 28th Feb 2023 | 00-24                    | 620   | 10                 | 610                                 | 340  | 270  |                                     |          |
| <b>Limiting Constraints</b>   |                          | N-1 contingency of 220 kV Magarwada(PG)-Magarwada(DD) D/C |                    |                                     |  |  |                                     |          |

**National Load Despatch Centre**  
**Import of Daman & Diu Transfer Capability for Feb 2023**

| <b>Revision No</b> | <b>Date of Revision</b> | <b>Period of Revision</b> | <b>Reason for Revision</b> |
|--------------------|-------------------------|---------------------------|----------------------------|
|                    |                         |                           |                            |

**National Load Despatch Centre**  
**Import of DNH Transfer Capability for Feb 2023**

Issue Date: 26th Oct 2022

Issue Time: 1700 hrs

Revision No. 0

| <b>Date</b>                   | <b>Time Period in IST (hrs)</b> | <b>Total Transfer Capability (TTC)</b>     | <b>Reliability Margin</b> | <b>Available Transfer Capability (ATC)</b> | <b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b> | <b>Margin Available for Short Term Open Access (STOA)</b> | <b>Changes in TTC w.r.t. Last Revision</b> | <b>Comments</b>                |
|-------------------------------|---------------------------------|--|---------------------------|--|---|---|--|--------------------------------|
| 1st Feb 2023 to 28th Feb 2023 | 00-24                           | 840  | 15                        | 825  | 1201  | 0   |  | Allocated LTA is more than ATC |
| <b>Limiting Constraints</b>   |                                 | N-1 contingency of 220 kV Kala-Khadoli D/C |                           |  |   |   |  |                                |

**National Load Despatch Centre**  
**Import of DNH Transfer Capability for Feb 2023**

| <b>Revision No</b> | <b>Date of Revision</b> | <b>Period of Revision</b> | <b>Reason for Revision</b> |
|--------------------|-------------------------|---------------------------|----------------------------|
|                    |                         |                           |                            |

**National Load Despatch Centre**  
**Import of DNHDDPDCL Transfer Capability for Feb 2023**

Issue Date: 26th Oct 2022

Issue Time: 1700 hrs

Revision No. 0

| Date                          | Time Period in IST (hrs) | Control area | Total Transfer Capability (TTC)  | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments   |
|-------------------------------|--------------------------|--------------|--|--------------------|-------------------------------------|--|--|-------------------------------------|--|
| 1st Feb 2023 to 28th Feb 2023 | 00-24                    | DNHDDPDCL    | 1310   | 25                 | 1285                                | 1540   | 0  |                                     | Limiting constraint will be same as defined for DNH and DD as separate control area. |
|                               | 00-24                    | DNH          | 840  | 15                 | 825                                 | 1201   | 0  |                                     | Allocated LTA is more than ATC   |
|                               | 00-24                    | DD           | 470  | 10                 | 460                                 | 340  | 0  |                                     |  |
| <b>Limiting Constraints</b>   |                          |              | DNH: N-1 contingency of 220 kV Kala-New Kharadpada- D/c<br>DD: N-1 contingency of 220 kV Magarwada-Magarwada(DD)-D/c |                    |                                     |  |  |                                     |  |

**\*\*This total TTC/ATC is for mentioning in SCADA and WRLDC website for DDDNH. In real time, ATC violations would be monitored separately for DD&DNH.**

**National Load Despatch Centre**  
**Import of DNHDDPDCL Transfer Capability for Feb 2023**

| <b>Revision No</b> | <b>Date of Revision</b> | <b>Period of Revision</b> | <b>Reason for Revision</b> |
|--------------------|-------------------------|---------------------------|----------------------------|
|                    |                         |                           |                            |

**National Load Despatch Centre**  
**Import of Goa Transfer Capability for Feb 2023**

Issue Date: 26th Oct 2022

Issue Time: 1700 hrs

Revision No. 0

| <b>Date</b>                   | <b>Time Period in IST (hrs)</b> | <b>Total Transfer Capability (TTC)</b>  | <b>Reliability Margin</b> | <b>Available Transfer Capability (ATC)</b> | <b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b> | <b>Margin Available for Short Term Open Access (STOA)</b> | <b>Changes in TTC w.r.t. Last Revision</b> | <b>Comments</b> |
|-------------------------------|---------------------------------|---|---------------------------|--|---|---|--|-----------------|
| 1st Feb 2023 to 28th Feb 2023 | 00-24                           | 710   | 15                        | 695  | 615   | 80  |  |                 |
| <b>Limiting Constraints</b>   |                                 | N-1 contingency of 220 kV Mapusa-Ponda-S/C & subsequent 220 kV & 110 kV voltages in Goa system are at the verge of 0.9 pu |                           |  |   |   |  |                 |

**National Load Despatch Centre**  
**Import of Goa Transfer Capability for Feb 2023**

| <b>Revision No</b> | <b>Date of Revision</b> | <b>Period of Revision</b> | <b>Reason for Revision</b> |
|--------------------|-------------------------|---------------------------|----------------------------|
|                    |                         |                           |                            |

**National Load Despatch Centre**  
**Import of Gujarat Transfer Capability for Feb 2023**

Issue Date: 26th Oct 2022

Issue Time: 1700 hrs

Revision No. 0

| Date                          | Time Period in IST (hrs) | Total Transfer Capability (TTC)   | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments  |
|-------------------------------|--------------------------|---|--------------------|-------------------------------------|--|--|-------------------------------------|---|
| <b>With SSP Generation</b>    |                          |   |                    |                                     |  |  |                                     |   |
| 1st Feb 2023 to 28th Feb 2023 | 00-09                    | 12820   | 370                | 12450                               | 10715  | 1735   |                                     | <a href="https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf">https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf</a> |
| 1st Feb 2023 to 28th Feb 2023 | 09-17                    | 12420   | 370                | 12050                               | 10715  | 1335   |                                     |   |
| 1st Feb 2023 to 28th Feb 2023 | 17-24                    | 12820   | 370                | 12450                               | 10715  | 1735   |                                     |   |
| <b>Without SSP Generation</b> |                          |   |                    |                                     |  |  |                                     |   |
| 1st Feb 2023 to 28th Feb 2023 | 00-09                    | 12620   | 370                | 12250                               | 10715  | 1535   |                                     | <a href="https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf">https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf</a> |
| 1st Feb 2023 to 28th Feb 2023 | 09-17                    | 12220   | 370                | 11850                               | 10715  | 1135   |                                     |   |
| 1st Feb 2023 to 28th Feb 2023 | 17-24                    | 12620   | 370                | 12250                               | 10715  | 1535   |                                     |   |
| <b>Limiting Constraints</b>   |                          | 1) Contingency of 400 kV Kankroli-Zerda-S/c and subsequent high loading on 400 kV Bhinmal-Zerda-S/c<br>2) N-1 contingency of 400 kV D/C Kala – Kudus line |                    |                                     |  |  |                                     |   |

**National Load Despatch Centre**  
**Import of Gujarat Transfer Capability for Feb 2023**

| <b>Revision No</b> | <b>Date of Revision</b> | <b>Period of Revision</b> | <b>Reason for Revision</b> |
|--------------------|-------------------------|---------------------------|----------------------------|
|                    |                         |                           |                            |

**National Load Despatch Centre**  
**Import of Madhya Pradesh Transfer Capability for Feb 2023**

Issue Date: 26th Oct 2022

Issue Time: 1700 hrs

Revision No. 0

| <b>Date</b>                    | <b>Time Period in IST (hrs)</b> | <b>Total Transfer Capability (TTC)</b> | <b>Reliability Margin</b> | <b>Available Transfer Capability (ATC)</b> | <b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b> | <b>Margin Available for Short Term Open Access (STOA)</b> | <b>Changes in TTC w.r.t. Last Revision</b> | <b>Comments</b>   |
|--------------------------------|---------------------------------|--|---------------------------|--|---|---|--|---|
| *1st Feb 2023 to 28th Feb 2023 | 00-24                           | 10800.00                               | 300                       | 10500.00                                   | 10827.62  | 0   |  | Link:-<br><a href="https://www.sldcmpindia.com/page.php?id=20">https://www.sldcmpindia.com/page.php?id=20</a> |
| <b>Limiting Constraints</b>    |                                 |  |                           |  |   |   |  |   |

\* TTC/ATC as declared by SLDC MP in website (Not available for Feb 2023. Hence, Oct22 TTC/ATC only considered for Feb'23 month also)

**National Load Despatch Centre**  
**Import of Madhya Pradesh Transfer Capability for Feb 2023**

| <b>Revision No</b> | <b>Date of Revision</b> | <b>Period of Revision</b> | <b>Reason for Revision</b> |
|--------------------|-------------------------|---------------------------|----------------------------|
|                    |                         |                           |                            |

**National Load Despatch Centre**  
**Import of Maharashtra Transfer Capability for Feb 2023**

Issue Date: 26th Oct 2022

Issue Time: 1700 hrs

Revision No. 0

| <b>Date</b>                   | <b>Time Period in IST (hrs)</b> | <b>Total Transfer Capability (TTC)</b> | <b>Reliability Margin</b> | <b>Available Transfer Capability (ATC)</b> | <b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b> | <b>Margin Available for Short Term Open Access (STOA)</b> | <b>Changes in TTC w.r.t. Last Revision</b> | <b>Comments</b> |
|-------------------------------|---------------------------------|--|---------------------------|--|---|---|--|-----------------|
| 1st Feb 2023 to 28th Feb 2023 | 00-24                           | 10060                                  | 300                       | 9760                                       | 9904  | 0   |  |                 |
| <b>Limiting Constraints</b>   |                                 | N-1 of 400 kV Parli-PG-Parli-MH-DC     |                           |  |   |   |  |                 |

**National Load Despatch Centre**  
**Import of Maharashtra Transfer Capability for Feb 2023**

| <b>Revision No</b> | <b>Date of Revision</b> | <b>Period of Revision</b> | <b>Reason for Revision</b> |
|--------------------|-------------------------|---------------------------|----------------------------|
|                    |                         |                           |                            |