

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Mar 2023

Issue Date: 25th Nov 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Mar 2023 to 31st Mar 2023	00-24	2590	50	2540	3451.41	0		
Limiting Constraints		N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs						

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Mar 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of DNHDDPDCL Transfer Capability for Mar 2023

Issue Date: 25th Nov 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Control area	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Mar 2023 to 31st Mar 2023	00-24	DNHDDPDCL	1310	25	1285	1463.85	0		Limiting constraint will be same as defined for DNH and DD as separate control area.
	00-24	DNH	840	15	825	1141.77	0		Allocated LTA is more than ATC
	00-24	DD	470	10	460	323.23	136.77		
Limiting Constraints			DNH: N-1 contingency of 220 kV Kala-New Kharadpada- D/c DD: N-1 contingency of 220 kV Magarwada-Magarwada(DD)-D/c						

****This total TTC/ATC is for mentioning in SCADA and WRLDC website for DNHDDPDCL. In real time, ATC violations would be monitored separately for DD&DNH.**

National Load Despatch Centre
Import of DNHDDPDCL Transfer Capability for Mar 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Goa Transfer Capability for Mar 2023

Issue Date: 25th Nov 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Mar 2023 to 31st Mar 2023	00-24	710	15	695	621	74		
Limiting Constraints		N-1 contingency of 220 kV Mapusa-Ponda-S/C & subsequent 220 kV & 110 kV voltages in Goa system are at the verge of 0.9 pu						

National Load Despatch Centre
Import of Goa Transfer Capability for Mar 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Gujarat Transfer Capability for Mar 2023

Issue Date: 25th Nov 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
With SSP Generation								
1st Mar 2023 to 31st Mar 2023	00-09	12820	370	12450	10705.7	1744.3		https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st Mar 2023 to 31st Mar 2023	09-17	12420	370	12050	10705.7	1344.3		
1st Mar 2023 to 31st Mar 2023	17-24	12820	370	12450	10705.7	1744.3		
Without SSP Generation								
1st Mar 2023 to 31st Mar 2023	00-09	12620	370	12250	10705.7	1544.3		https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st Mar 2023 to 31st Mar 2023	09-17	12220	370	11850	10705.7	1144.3		
1st Mar 2023 to 31st Mar 2023	17-24	12620	370	12250	10705.7	1544.3		
Limiting Constraints		1) Contingency of 400 kV Kankroli-Zerda-S/c and subsequent high loading on 400 kV Bhinmal-Zerda-S/c 2) N-1 contingency of 400 kV D/C Kala – Kudus line						

National Load Despatch Centre
Import of Gujarat Transfer Capability for Mar 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for Mar 2023

Issue Date: 25th Nov 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
* 1st Mar 2023 to 31st Mar 2023	00-24	10705.00	300	10405.00	10861.90	-457		Link:- https://www.sldcmpindia.com/page.php?id=20
Limiting Constraints								

* TTC/ATC as declared by SLDC MP in website (Not available for Mar 2023. Hence, Nov'22 TTC/ATC only considered for Mar'23 month also)

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for Mar 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Maharashtra Transfer Capability for Mar 2023

Issue Date: 25th Nov 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Mar 2023 to 31st Mar 2023	00-24	10060	300	9760	9896.47	0		
Limiting Constraints		N-1 of 400 kV Parli-PG-Parli-MH-DC						

National Load Despatch Centre
Import of Maharashtra Transfer Capability for Mar 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision