

**National Load Despatch Centre**  
**Import of Chhattisgarh Transfer Capability for May 2023**

Issue Date: 26th Jan 2023

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00-24	2590	50	2540	3918.07	0		
<b>Limiting Constraints</b>		N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs						

**National Load Despatch Centre**  
**Import of Chhattisgarh Transfer Capability for May 2023**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>

**National Load Despatch Centre**  
**Import of DNHDDPDCL Transfer Capability for May 2023**

Issue Date: 26th Jan 2023

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Control area	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00-24	DNHDDPDCL	1310	25	1285	1463.85	0		Limiting constraint will be same as defined for DNH and DD as separate control area.
	00-24	DNH	840	15	825	1141.77	0		Allocated LTA is more than ATC
	00-24	DD	470	10	460	323.23	136.77		
<b>Limiting Constraints</b>			DNH: N-1 contingency of 220 kV Kala-New Kharadpada- D/c DD: N-1 contingency of 220 kV Magarwada-Magarwada(DD)-D/c						

**\*\*This total TTC/ATC is for mentioning in SCADA and WRLDC website for DNHDDPDCL. In real time, ATC violations would be monitored separately for DD&DNH.**

**National Load Despatch Centre**  
**Import of DNHDDPDCL Transfer Capability for May 2023**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>

**National Load Despatch Centre**  
**Import of Goa Transfer Capability for May 2023**

Issue Date: 26th Jan 2023

Issue Time: 1700 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May 2023 to 31st May 2023	00-24	710	15	695	625	70		
<b>Limiting Constraints</b>	N-1 contingency of 220 kV Mapusa-Ponda-S/C & subsequent 220 kV & 110 kV voltages in Goa system are at the verge of 0.9 pu							

**National Load Despatch Centre**  
**Import of Goa Transfer Capability for May 2023**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>

**National Load Despatch Centre**  
**Import of Gujarat Transfer Capability for May 2023**

Issue Date: 26th Jan 2023

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
<b>With SSP Generation</b>								
1st May 2023 to 31st May 2023	00-09	12820	370	12450	10735.74	1714.26		<a href="https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf">https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf</a>
1st May 2023 to 31st May 2023	09-17	12420	370	12050	10735.74	1314.26		
1st May 2023 to 31st May 2023	17-24	12820	370	12450	10735.74	1714.26		
<b>Without SSP Generation</b>								
1st May 2023 to 31st May 2023	00-09	12620	370	12250	10735.74	1514.26		<a href="https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf">https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf</a>
1st May 2023 to 31st May 2023	09-17	12220	370	11850	10735.74	1114.26		
1st May 2023 to 31st May 2023	17-24	12620	370	12250	10735.74	1514.26		
<b>Limiting Constraints</b>		1) Contingency of 400 kV Kankroli-Zerda-S/c and subsequent high loading on 400 kV Bhinmal-Zerda-S/c 2) N-1 contingency of 400 kV D/C Kala – Kudus line						

**National Load Despatch Centre**  
**Import of Gujarat Transfer Capability for May 2023**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>

**National Load Despatch Centre**  
**Import of Madhya Pradesh Transfer Capability for May 2023**

Issue Date: 26th Jan 2023

Issue Time: 1700 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
*1st May 2023 to 31st May 2023	00-24	11709.00	340	11369.00	10861.90	507		Link:- <a href="https://www.sldcmpindia.com/page.php?id=20">https://www.sldcmpindia.com/page.php?id=20</a>
<b>Limiting Constraints</b>								

\* TTC/ATC as declared by SLDC MP in website (Not available for May 2023. Hence, Jan'23 TTC/ATC only considered for May'23 month also)

**National Load Despatch Centre**  
**Import of Madhya Pradesh Transfer Capability for May 2023**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>

**National Load Despatch Centre**  
**Import of Maharashtra Transfer Capability for May 2023**

Issue Date: 26th Jan 2023

Issue Time: 1700 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st May 2023 to 31st May 2023	00-24	10060	300	9760	9896.47	-136		
<b>Limiting Constraints</b>	1) N-1 contingency of 400 kV Chandrapur-Chandrapur-II-D/c, 2) N-1 contingency of 400 kV New Parli(PG)-Parli-MH-DC, 3)N-1 contingency of 2x1500 MVA, 765/400 kV Ektuni ICTs, 4)N-1 contingency of 400 kV Pune(GIS)-Pune(PG)-Q/c lines							

**National Load Despatch Centre**  
**Import of Maharashtra Transfer Capability for May 2023**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>