

Rev-0									26.07.2023
State	Date	Time Period (hrs)	TTC (MW)	TRM (MW)	ATC (MW)	Share allocation /LT A/MTOA (MW)	Margin (ATC-share allocation/LT A/MTOA) (MW)	Limiting Constraint	Remarks
Maharashtra	01 <sup>st</sup> Nov-30 <sup>th</sup> Nov' 23	00-24	10060	300	9760	10727	-967	1. N-1 contingency of 400 kV Chandrapur-Chandrapur-II-D/c 2. N-1 contingency of 400 kV New Parli (PG)-Parli-MH-DC 3. N-1 contingency of 765/400 kV Ektuni ICTs 4. N-1 contingency of 400 kV Pune(GIS)-Pune(PG)-Q/c	
#Gujarat	01 <sup>st</sup> Nov-30 <sup>th</sup> Nov' 23	00-09	12820	370	12450	10928	1522	1 Contingency of 400 kV Kankroli-Zerda-S/c and subsequent high loading on 400 kV Bhinmal-Zerda-S/c 2. N-1 contingency of 400 kV Kudus-Kala-DC	If SSP Generation : <b>450 MW</b>
		09-17	12420	370	12050	10928	1122		
		17-24	12820	370	12450	10928	1522		
		00-09	12620	370	12250	10928	1322		If SSP Generation : <b>50 MW</b>
		09-17	12220	370	11850	10928	922		
		17-24	12620	370	12250	10928	1322		

*Madhya Pradesh	01 <sup>st</sup> Nov-30 <sup>th</sup> Nov' 23	00-24	10746	312	10434	10801	-367		
Chhattisgarh	01 <sup>st</sup> Nov-30 <sup>th</sup> Nov' 23	00-24	2590	50	2540	4017.61	-1478	N-1 contingency of (a)400/220 kV Bhatapara ICTs, (b) 400/220 kV NSPCL ICTs, (c) 400/220kV Raigarh-PG ICTs	
Goa	01 <sup>st</sup> Nov-30 <sup>th</sup> Nov' 23	00-24	710	15	695	636	59	N-1 contingency of 220 kV Mapusa-Ponda-S/C & subsequent 220 kV & 110 kV voltages in Goa system are at the verge of 0.9 pu.	
DNHDDPDC L	01 <sup>st</sup> Nov-30 <sup>th</sup> Nov' 23	00-24	1310	25	1285	1555	-270	a) N-1 contingency of 220 kV Magarwada (PG)-Magarwada (DD) D/C b) N-1 contingency of 220 kV Kala-Khadoli D/C	
^DD	01 <sup>st</sup> Nov-30 <sup>th</sup> Nov' 23	00-24	470	10	460	342	118	N-1 contingency of 220 kV Magarwada (PG)-Magarwada (DD) D/C	
^DNH	01 <sup>st</sup> Nov-30 <sup>th</sup> Nov' 23	00-24	840	15	825	1213	-388	N-1 contingency of 220 kV Kala-Khadoli D/C	
# <a href="https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf">https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf</a>									

\* <https://www.sldcmpindia.com/page.php?id=20> (Updated as per SLDC MP declaration)

^ For monitoring of DNH and DD ATC in real time system operation