

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Oct 2022

Issue Date: 26th June 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Oct 2022 to 31st Oct 2022	00-24	2590	50	2540	3448.91	0		
Limiting Constraints	N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs							

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Oct 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Goa Transfer Capability for Oct 2022

Issue Date: 26th June 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Oct 2022 to 31st Oct 2022	00-24	710	15	695	588	107		
Limiting Constraints	N-1 contingency of 220 kV Mapusa-Ponda-S/C							

National Load Despatch Centre
Import of Goa Transfer Capability for Oct 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Gujarat Transfer Capability for Oct 2022

Issue Date: 26th June 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
With SSP Generation								
1st Oct 2022 to 31st Oct 2022	00-09	10230	330	9900	10189.03	0		https://www.slcdguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st Oct 2022 to 31st Oct 2022	09-17	9830	330	9500	10189.03	0		
1st Oct 2022 to 31st Oct 2022	17-24	10230	330	9900	10189.03	0		
Without SSP Generation								
1st Oct 2022 to 31st Oct 2022	00-09	10030	330	9700	10189.03	0		https://www.slcdguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf
1st Oct 2022 to 31st Oct 2022	09-17	9630	330	9300	10189.03	0		
1st Oct 2022 to 31st Oct 2022	17-24	10030	330	9700	10189.03	0		
Limiting Constraints		1) N-1 contingency of 400 kV D/C Banaskantha – Veloda line. 2) N-1 contingency of 400 kV D/C Kala – Kudus line						

National Load Despatch Centre
Import of Gujarat Transfer Capability for Oct 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for Oct 2022

Issue Date: 26th June 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
*1st Oct 2022 to 31st Oct 2022	00-24	10978.00	300	10678.00	10897.70	0		Link:- https://www.sldcmpindia.com/page.php?id=20
Limiting Constraints								

* TTC/ATC as declared by SLDC MP in website (Not available for Oct 2022. Hence, June'22 TTC/ATC only considered for Oct'22 month also)

National Load Despatch Centre
Import of Madhya Pradesh Transfer Capability for Sept 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision

National Load Despatch Centre
Import of Maharashtra Transfer Capability for Oct 2022

Issue Date: 26th June 2022

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Oct 2022 to 31st Oct 2022	00-24	10060	300	9760	9889.82	0		
Limiting Constraints	N-1 of 400 kV Parli-PG-Parli-MH-DC							

National Load Despatch Centre
Import of Maharashtra Transfer Capability for Oct 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision