

WRLDC, Grid India
Total Transfer Capability for Dec'25

Issue date: 26 Dec'24

Rev-0

| S.N | Corridor/Control Area | Date | Time Period | Time Blocks | Total Transfer Capability (TTC) (MW) | Reliability Margin (RM) (MW) | Available Transfer Capability (ATC) (MW) | Approved GNA (MW) | Margin for T-GNA (MW) | Changes in TTC w.r.t last revision | Remarks |
|-----|-----------------------|----------------------|-------------|-------------|--------------------------------------|------------------------------|--|-------------------|-----------------------|------------------------------------|--|
| 1 | Maharashtra | 01st Dec-31st Dec'25 | 00-24 | 0-96 | 11400 | 600 | 10800 | 9646.00 | 1154 | - | |
| 2 | #Gujarat | 01st Dec-31st Dec'25 | 00-09 | 0-36 | 12820 | 370 | 12450 | 11903.67 | 546.33 | - | If SSP Generation: 450 MW |
| | | 01st Dec-31st Dec'25 | 09-17 | 37-68 | 12420 | 370 | 12050 | 11903.67 | 146.33 | - | |
| | | 01st Dec-31st Dec'25 | 17-24 | 69-96 | 12820 | 370 | 12450 | 11903.67 | 546.33 | - | |
| | | 01st Dec-31st Dec'25 | 00-09 | 0-36 | 12620 | 370 | 12250 | 11903.67 | 346.33 | - | If SSP Generation: 50 MW |
| | | 01st Dec-31st Dec'25 | 09-17 | 37-68 | 12220 | 370 | 11850 | 11903.67 | 0 | - | |
| | | 01st Dec-31st Dec'25 | 17-24 | 69-96 | 12620 | 370 | 12250 | 11903.67 | 346.33 | - | |
| 3 | *Madhya Pradesh | 01st Dec-31st Dec'25 | 00-24 | 0-96 | 13682 | 383 | 13298 | 10587 | 2711 | - | The TTC/ATC figures as published by MPSLDC |
| 4 | Chattisgarh | 01st Dec-31st Dec'25 | 00-24 | 0-96 | 3649 | 113 | 3536 | 3536 | 0 | - | |
| 5 | Goa | 01st Dec-31st Dec'25 | 00-24 | 0-96 | 710 | 15 | 695 | 673 | 22 | - | |
| 6 | DNHDDPCL | 01st Dec-31st Dec'25 | 00-24 | 0-96 | 1310 | 25 | 1285 | 1206 | 79 | - | |
| 7 | ^DD | 01st Dec-31st Dec'25 | 00-24 | 0-96 | 470 | 10 | 460 | 384 | 76 | - | |
| 8 | ^DNH | 01st Dec-31st Dec'25 | 00-24 | 0-96 | 840 | 15 | 825 | 822 | 3 | - | |

Limiting Constraints :-

| Corridor/Control Area | Constraints | Remarks |
|-----------------------|---|---|
| Maharashtra | 1. Critical loading on 400 kV Pune (PG)- Chakan-5/c and 400kV Pune-Lonikhand-5/c 2. Critical loading on 400 kV Pune (PG)- Pune(PG)-QJ/C under N-1 condition. 3. Contingency of 500 MVA, 400/220 kV Padghe ICT-4 or 500 MVA, 400/220 kV Padghe ICT-5 and subsequent high loading on other ICTs 4. N-1 contingency of 2x 315 MVA, 400/220 kV Navi Mumbai ICTs 5. Contingency of 500 MVA, 400/220 kV Bolar ICT-3 or 4 and subsequent high loading on other ICTs 6. Contingency of 500 MVA, 400/220 kV Nagothane ICT-3 and subsequent high loading on other ICTs 7. N-1 contingency of 500 MVA, 400/220 kV Thapsttanda ICT-1 & 2 8. Critical loading and low voltages on the intra state elements in Pune, Mumbai, Solapur and Nashik area | |
| Gujarat | 1. N-1 contingency of 400 kV Banaskantha-Veloda-D/c 2. High loading on 400 kV Banaskantha-Zerda-5/c 3. N-1 contingency of 400 kV Kankroli-Zerda-D/c 4. High loading on 400 kV Asoj-Kosamba-5/c 5. High loading on 400 kV Navsari-Vav(GI)-5/c 6. Low voltages at Jetpur, Amreli, Hadala and nearby areas | # https://www.sldgji.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf |
| Madhya Pradesh | 1. N-1 contingency of 2x315 MVA, 400/220 kV Julwani ICTs 2. Contingency of 500 MVA, 400/220 kV Jabalpur ICT-3 and subsequent high loading on other ICTs 3. Contingency of 500 MVA, 400/220 kV Bilopal ICT-1 or 4 and subsequent high loading on other ICTs | * https://www.sldgindia.com/page.php?id=20 (Updated as per SLDG MP declaration) |
| Chattisgarh | 1. N-1 contingency of 400/220 kV Raipur ICTs 2. N-1 contingency of 400/220 kV NSPCL ICTs | |
| GOA | N-1 contingency of 220 kV Mapusa-Ponda-5/c & subsequent 220 kV & 110 kV voltages in Goa system are at the verge of 0.9 pu. | |
| DDDNHPDCL | | |
| DD | N-1 contingency of 220 kV Magarwada (PG)-Magarwada (DD) D/C | ^ For monitoring of DNH and DD ATC in real time system operation |
| DNH | N-1 contingency of 220 kV Kala-Khadoli D/C | ^ For monitoring of DNH and DD ATC in real time system operation |

WRLDC, Grid India
Import/Export Capability of Control area

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |