

GRID CONTROLLER OF INDIA LIMITED
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, WRLDC/SRLDC

Date: 4/13/2024
Time: 2:11:06 AM

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	WR-SR	16100	15450	15300	14650	-800	2024-04-13	7	24	Due to the tripping of 765kV Warora - Warangal -2
2	WR-SR	16400	15750	15600	14950	-800	2024-04-13	25	32	Due to the tripping of 765kV Warora - Warangal -2
3	WR-SR	16100	15450	15300	14650	-800	2024-04-13	33	60	Due to the tripping of 765kV Warora - Warangal -2
4	WR-SR	16400	15750	15600	14950	-800	2024-04-13	61	68	Due to the tripping of 765kV Warora - Warangal -2
5	WR-SR	16100	15450	15300	14650	-800	2024-04-13	69	96	Due to the tripping of 765kV Warora - Warangal -2
6	SR_IMPORT	21850	20850	21050	20050	-800	2024-04-13	7	24	Due to the tripping of 765kV Warora - Warangal -2
7	SR_IMPORT	22150	21150	21350	20350	-800	2024-04-13	25	32	Due to the tripping of 765kV Warora - Warangal -2
8	SR_IMPORT	21850	20850	21050	20050	-800	2024-04-13	33	60	Due to the tripping of 765kV Warora - Warangal -2
9	SR_IMPORT	22150	21150	21350	20350	-800	2024-04-13	61	68	Due to the tripping of 765kV Warora - Warangal -2
10	SR_IMPORT	21850	20850	21050	20050	-800	2024-04-13	69	96	Due to the tripping of 765kV Warora - Warangal -2

SCE-NLDC