

GRID CONTROLLER OF INDIA LIMITED
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, NRLDC

Date: 10/23/2023
Time: 4:49:34 PM

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	NR-WR	3600	3100	2900	2400	-700	2023-10-23	62	96	Outage of 765 kV Indore - Vadodara S/C
2	NR_EXPORT	3600	3100	2900	2400	-700	2023-10-23	62	96	Outage of 765 kV Indore - Vadodara S/C

SCE-NLDC